

## *Reportable Events Filed in 2017*

Date Reported	Stn	Report #	title
Jan 3, 2017	B	B-2017-28596939	Unit 6 - Loose Contamination
Jan 4, 2017	A	B-2017-28597416	Unit 1 Setback
Jan 9, 2017	A	B-2017-28598494	Incomplete REGDOC-3.1.1 Scheduled Report
Jan 10, 2017	A	B-2017-28598037	Fire Preventative Maintenance (PM) Testing Exceeded Due Date
Jan 12, 2017	B	B-2017-28598419	Category C Spill - Oil Leak in Pumphouse
Jan 17, 2017	B	B-2017-28599304	Relief Valve Nuclear Sampling Requirements Not Met
Jan 23, 2017	B	B-2017-28599829	Unposted Radiological Hazard
Jan 27, 2017	A	B-2017-28601815	Fuel Handling Relief Valve Mandatory Testing Missed
Jan 27, 2017	B	B-2017-28601126	Unposted Radiological Hazard
Feb 1, 2017	A	B-2017-28602507	Motor Oil Category C Spill
Feb 1, 2017	A	B-2017-28602112	ECI Valve Opened too Quickly
Feb 3, 2017	B	B-2017-28602658	Unit 7 Shutdown
Feb 6, 2017	A	B-2017-28602635	Domestic Water Spill
Feb 8, 2017	B	B-2017-28603567	Unit 5 Unplanned Actuation of Shutdown System #1 (SDS1)
Feb 8, 2017	A	B-2017-28595527	BA Analysis for Break on Top of Pressurizer Shows Reduced Margin
Feb 16, 2017	A	B-2017-28604612	Incomplete Records
Feb 21, 2017	A	B-2017-28605217	Less Than Minimum Number of Standby Generators Available
Feb 22, 2017	A	B-2017-28606176	Reactor Inner Zone Inlet Header (RIZIH)
Feb 22, 2017	A	B-2017-28604140	Missed Online Safety System Test
Feb 22, 2017	B	B-2017-28605220	Public Address Speaker blocked
Mar 6, 2017	B	B-2017-28606484	Radiolysis in End Shield Cooling
Mar 8, 2017	A	B-2017-28608361	Missed Monthly Fire Test
Mar 9, 2017	B	B-2017-28607692	Tritium Monitor Alarm Disabled
Mar 13, 2017	B	B-2017-28609891	Heat Sink Boiler Impaired
Mar 14, 2017	AB	B-2017-28606967	Pressure Tube Fracture Toughness from BT-29 Below CSA LB Curve
Mar 14, 2017	B	B-2017-28609464	Unposted Radiological Hazard
Mar 20, 2017	B	B-2017-28611051	Unit 6 Turbine Runback
Mar 28, 2017	B	B-2017-28612767	Worker Injured
Apr 12, 2017	B	B-2017-28614774	Public Address Speaker Function Compromised

Apr 13, 2017	A	B-2017-28614744	Preventative Maintenance Not Completed Per Schedule
Apr 21, 2017	B	B-2017-28615220	Certification Procedure Insufficient
Apr 24, 2017	A	B-2017-28616957	Station Shift Complement
Apr 24, 2017	A	B-2017-28617433	Unit 4 Emergency Coolant Injection System (ECI)
Apr 25, 2017	B	B-2017-28616768	Potential Exceedance of ECA Discharge Criteria
Apr 25, 2017	B	B-2017-28617918	Flame Observed during Pump Motor Return to Service
May 1, 2017	A	B-2017-28614406	Periodic Inspection Not Completed per Schedule
May 4, 2017	AB	B-2017-28616745	Characteristics of Emergency Transfer Scheme
May 12, 2017	B	B-2017-28620047	Unit 6 Stepback Impairment
May 16, 2017	B	B-2017-28621101	Unit 5 Stepback
May 17, 2017	B	B-2017-28621519	Level 2 Impairment of Shutdown System 2
May 17, 2017	B	B-2017-28620877	Radiation Safety Equipment Unplugged
May 19, 2017	A	B-2017-28621508	Unit 4 Unplanned Reactor Shutdown
May 23, 2017	B	B-2017-28622029	Unit 5 Turbine Tripped Manually
May 26, 2017	B	B-2017-28622539	Radioactive Shipments Packaging Damaged
Jun 13, 2017	A	B-2017-28626140	Mandatory Relief Valve Testing Not Completed
Jun 16, 2017	B	B-2017-28624527	Preventative Maintenance Tests Overdue
Jun 16, 2017	A	B-2017-28626196	SDS1/2 Impairment during Testing
Jun 20, 2017	A	B-2017-28626375	Minimum Shift Complement not met
Jun 21, 2017	B	B-2017-28626458	Unit 7 Forced Outage
Jul 6, 2017	B	B-2017-28625025	Possible Emergency Coolant Injection Impairment
Jul 13, 2017	A	B-2017-28630373	Mandatory Relief Valve Testing Missed
Jul 21, 2017	A	B-2017-28631630	Unit 1 Actuation of Shutdown System 1
Jul 21, 2017	A	B-2017-28632102	Unit 2 Change of Reactor Power
Aug 2, 2017	B	B-2017-28633177	Air Conditioning Reheat Hot Water Leak
Aug 3, 2017	B	B-2017-28633812	Below Minimum Complement
Aug 9, 2017	A	B-2017-28634560	Unit 3 Primary Heat Transport Pump Motor Seal Failure
Aug 18, 2017	B	B-2017-28635840	Air Conditioning Reheat Hot Water Spill
Aug 21, 2017	B	B-2017-28636327	Controlled Nuclear Information Exported without a Licence
Aug 30, 2017	B	B-2017-28637854	Unit 7 Unplanned Reactor Power Change
Sep 12, 2017	B	B-2017-28638393	Annual FAGM Calibration Preventative Maintenance Overdue
Sep 14, 2017	B	B-2017-28639366	Impairment due to Elevated Continuous Boiler Blowdown
Sep 25, 2017	A	B-2017-28640316	Mandatory Relief Valve Testing Missed
Sep 25, 2017	A	B-2017-28642584	Impairment of Emergency Coolant Injection System
Sep 29, 2017	B	B-2017-28643642	Late Report to CNSC
Sep 29, 2017	B	B-2017-28641968	Broken IAEA Seal

Oct 4, 2017	B	B-2017-28644499	Impairment of SDS1 and SDS2
Oct 13, 2017	A	B-2017-28644769	Periodic Inspection Not Completed as per Schedule
Oct 17, 2017	B	B-2017-28646212	Unposted Hazard
Oct 17, 2017	AB	B-2017-28646891	Late Report of Employee Illness
Oct 17, 2017	AB	B-2017-28642918	Employee Illness during Training
Oct 20, 2017	B	B-2017-28648307	Late Detailed Report
Oct 26, 2017	B	B-2017-28649012	Unit 7 Setback
Oct 27, 2017	A	B-2017-28648650	Unposted Hazard
Oct 31, 2017	B	B-2017-28649826	Unposted Radiological Hazard in Unit 7
Nov 7, 2017	A	B-2017-28651385	Safety System Tests Not Deferred Per Process
Nov 14, 2017	A	B-2017-28650556	Legacy Bruce A Mandatory Fire Preventative Maintenance Testing Exceeded Due Date
Nov 14, 2017	B	B-2017-28652191	Late Reporting of Spill
Nov 14, 2017	B	B-2017-28634397	Domestic Water Leak
Nov 14, 2017	A	B-2017-28652458	Unit 4 Reactor Inner Zone Inlet Header (RIZIH) Impairment
Nov 14, 2017	B	B-2017-28652413	Below Minimum Complement
Nov 15, 2017	A	B-2017-28651057	Loose Contamination in Zone 1
Nov 17, 2017	AB	B-2017-28652400	Controlled Nuclear Information Export without a Licence
Nov 21, 2017	A	B-2017-28650625	Unit 3 SDS1 and SDS2 Impairment
Nov 22, 2017	A	B-2017-28654013	Unit 2 Pumphouse Sump Acute Lethality Test Failure
Nov 29, 2017	AB	B-2017-28654464	Class III Power Unavailable during Testing
Nov 30, 2017	B	B-2017-28655437	Domestic Water Release
Dec 7, 2017	B	B-2017-28656368	Public Address Speaker System Out of Service
Dec 15, 2017	AB	B-2017-28642604	Potential for Insufficient Gadolinium Insertion Rate
Dec 15, 2017	AB	B-2017-28656320	Issue with Dose Calculation for Moderator Analysis
Dec 20, 2017	B	B-2017-28658538	Small Fire in Vehicle