


# Periodic Safety Review - Final Document Review Traveler



Bruce Power Document #: NK29-SFR-09701-00014	Revision: R000	Information Classification Internal Use Only	Usage Classification Information
Bruce Power Document Title: Safety Factor 14 - Radiological Impact on the Environment			
Bruce Power Contract/Purchase Order: 00193829	Bruce Power Project #: 39075		
Supplier's Name: CANDESCO	Supplier Document #: K-421231-00214	Revision: R00	
Supplier Document Title: Safety Factor 14 - Radiological Impact on the Environment			

Accepted for use at Bruce Power by:	Signature:	Date
Name: James Scongack Title: Vice President, Corporate Affairs	 James Scongack 2016.09.29	11:22:16 -0400

Acceptance of this document does not relieve the  
Supplier of responsibility for any errors or omissions

# Periodic Safety Review - Final Document Review Traveler

 Sheet # 2 of 3

Bruce Power Document #:	NK29-SFR-09701-00014	Rev #: R000	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:	Safety Factor 14 - Radiological Impact on the Environment	Suppliers Name:	CANESCO	
Bruce Power Contract/ Purchase Order:	00193829	Supplier Document Title:	Safety Factor 14 - Radiological Impact on the Environment	
Bruce Power Project #:	39075	Supplier Document:	K-421231-00214	Rev #: R00

## Reviewed By:

Name	Title	Department	Signature	Date
Cheryl Smith	Sr. Technical Officer	Environment Programs	electronic acceptance	24Aug2016
Danielle LaCroix (RegC AR 28562975.02)	Section Manager	Environment Programs	<i>Danielle LaCroix</i>	27SEP2016

## Recommended for Use By:


Name	Title	Department	Signature	Date
Francis Chua (RegC AR 28562975)	Department Manager	Environment & Sustainability	<i>Francis Chua</i>	27SEP2016

# Periodic Safety Review - Final Document Review Traveler


 Sheet # 3 of 3

Bruce Power Document #:	NK29-SFR-09701-00014	Rev #: R000	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:	Safety Factor 14 - Radiological Impact on the Environment	Suppliers Name:	CANDESCO	
Bruce Power Contract/ Purchase Order:	00193829	Supplier Document Title:	Safety Factor 14 - Radiological Impact on the Environment	
Bruce Power Project #:	39075	Supplier Document:	K-421231-00214	Rev #: R000

## Reviewed By:

Name	Title	Department	Signature	Date
Michael Latimer (RegC AR 28563010.02)	Department Manager	Safety Programs		21 Sept 2016

## Recommended for Use By:

Name	Title	Department	Signature	Date
Linda Peerla Proulx (RegC AR 28563010)	Division Manager	Nuclear Programs		22/09/16

# Periodic Safety Review - Final Document Review Traveler

Sheet # \_\_\_\_\_ of \_\_\_\_\_

Bruce Power Document #:		Rev #:	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:		Suppliers Name:		
Bruce Power Contract/ Purchase Order:		Supplier Document Title:		
Bruce Power Project #:		Supplier Document:		Rev #:

<b>Reviewed By:</b>				
Name	Title	Department	Signature	Date

<b>Recommended for Use By:</b>				
Name	Title	Department	Signature	Date

Periodic Safety Review - Final Document Review Traveler

Sheet # \_\_\_\_\_ of \_\_\_\_\_

Bruce Power Document #:	Rev #:	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:	Suppliers Name:		
Bruce Power Contract/ Purchase Order:	Supplier Document Title:		
Bruce Power Project #:	Supplier Document:		Rev #:

Reviewed By:			
Name	Title	Department	Date

Recommended for Use By:			
Name	Title	Department	Date

Periodic Safety Review - Final Document Review Traveler

Sheet # \_\_\_\_\_ of \_\_\_\_\_

Bruce Power Document #:		Rev #:	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:		Suppliers Name:		
Bruce Power Contract/ Purchase Order:		Supplier Document Title:		
Bruce Power Project #:		Supplier Document:		Rev #:

Reviewed By:				
Name	Title	Department	Signature	Date

Recommended for Use by:			
Name	Title	Department	Date

# Periodic Safety Review - Final Document Review Traveler

Sheet # \_\_\_\_\_ of \_\_\_\_\_

Bruce Power Document #:		Rev #:	Information Classification: Internal Use Only	Usage Classification: Information
Bruce Power Document Title:		Suppliers Name:		
Bruce Power Contract/ Purchase Order:		Supplier Document Title:		
Bruce Power Project #:		Supplier Document:		Rev #:

Reviewed By:				
Name	Title	Department	Signature	Date

Recommended for Use By:			
Name	Title	Department	Date




**NK29-SFR-09701-00014**

**Title: Safety Factor 14 - Radiological  
Impact on the Environment**


**File: K-421231-00214-R00**







**A Report Submitted to Bruce Power  
September 20, 2016**




 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

<b>Issue</b>  R00D0	<b>Reason for Issue:</b>  For harmonization				
	Author: R. Hirning N. Fajurally	Verifier:	Reviewer: L. Watt	Approver:	Date: Apr. 12, 2016
<b>Issue</b>  R00D1	<b>Reason for Issue:</b>  For internal review				
	Author: R. Hirning N. Fajurally	Verifier:	Reviewer: L. Watt M. Grey	Approver:	Date: Apr. 20, 2016
<b>Issue</b>  R00D2	<b>Reason for Issue:</b>  For Bruce Power review				
	Author: R. Hirning N. Fajurally	Verifier: G. Buckley	Reviewer: L. Watt M. Grey	Approver:	Date: May 17, 2016
<b>Issue</b>  R00D3	<b>Reason for Issue:</b>  Addresses Bruce Power review comments and internal verification comments.				
	Author: R. Hirning N. Fajurally	Verifier: G. Buckley	Reviewer: L. Watt M. Grey	Approver:	Date: August 24, 2016


	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Issue  R00	Reason for Issue:				
	For use				
	Author: R. Hirning  N. Fajurally 	Verifier: G. Buckley 	Reviewer: L. Watt  M. Grey 	Approver: L. Watt 	Date: Sept 20, 2016
Document Classification: Report			Security Classification: Client Proprietary		


	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## Table of Contents

<b>Acronyms and Abbreviations .....</b>	<b>vii</b>
<b>1. Objective and Description .....</b>	<b>1</b>
1.1. Objective .....	1
1.2. Description .....	2
<b>2. Methodology of Review .....</b>	<b>3</b>
<b>3. Applicable Codes and Standards .....</b>	<b>5</b>
3.1. Acts and Regulations .....	5
3.2. Power Reactor Operating Licence .....	5
3.3. Regulatory Documents .....	10
3.4. CSA Standards .....	10
3.5. International Standards .....	11
3.6. Other Applicable Codes and Standards .....	12
<b>4. Overview of Applicable Bruce B Station Programs and Processes .....</b>	<b>12</b>
4.1. Level 0 Document .....	12
4.2. Level 1 Document .....	14
4.3. Level 2 Documents .....	15
4.4. Level 3 Documents .....	16
<b>5. Results of the Review Tasks .....</b>	<b>17</b>
5.1. Appropriateness of Monitoring Program .....	17
5.2. Concentrations of Radionuclides and Corrective Actions .....	18
5.3. Potential New Sources of Radiological Impact .....	19
5.4. Sampling and Measurement Methods .....	20
5.5. Effluent Discharge Records: Monitoring, Trending and Responding .....	20
5.6. On-Site Monitoring and Prompt Detection .....	21
5.7. Off-Site Monitoring and Corrective Actions .....	23
5.8. Contamination Levels .....	24
5.9. Alarm Systems Responding to Unplanned Releases of Radioactive Material .....	25
5.10. Publication of Environmental Data .....	26
5.11. Changes in the Use of Areas Around the Site .....	28
<b>6. Interfaces with Other Safety Factors .....</b>	<b>28</b>
<b>7. Program Assessments and Adequacy of Implementation .....</b>	<b>29</b>
7.1. Self-Assessments .....	30
7.2. Internal and External Audits and Reviews .....	33
7.2.1. Internal Audits .....	33
7.2.2. External Audits and Reviews .....	35
7.3. Regulatory Evaluations and Reviews .....	36
7.4. Performance Indicators .....	38
<b>8. Summary and Conclusions .....</b>	<b>39</b>
<b>9. References .....</b>	<b>41</b>
<b>Appendix A – High-Level Assessments Against Relevant Codes and Standards A-</b>	<b>A-</b>


 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

<b>A.1. CSA N288.1-14 Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities</b>	<b>A-1</b>
<b>A.2. CSA N288.4-10, Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills .....</b>	<b>A-2</b>
<b>A.3. CSA N288.5-11, Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills .....</b>	<b>A-2</b>
<b>A.4. CSA N288.6-12, Environmental risk assessments at Class I nuclear facilities and uranium mines and mills .....</b>	<b>A-2</b>
<b>A.5. IAEA NS-G-3.2, Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants.....</b>	<b>A-3</b>
<b>A.6. CNSC G-129, Revision 1, Keeping Radiation Exposures and Doses “As Low As Reasonably Achievable” .....</b>	<b>A-3</b>
<b>A.7. ANSI/HPS N13.1-1999 (R2011), Sampling and Monitoring Releases of Airborne Radioactive Substances From the Stacks and Ducts of Nuclear Facilities .....</b>	<b>A-4</b>
<b>A.8. CNSC G-228, Developing and Using Action Levels.....</b>	<b>A-4</b>
<b>A.9. CSA N288.3.4-13, Performance testing of nuclear air-cleaning systems at nuclear facilities .....</b>	<b>A-5</b>
<b>A.10. CSA N288.7-15, Groundwater protection programs at Class I nuclear facilities and uranium mines and mills .....</b>	<b>A-8</b>
<b>Appendix B – Clause-By-Clause Assessments Against Relevant Codes and Standards .....</b>	<b>B-1</b>

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


## List of Tables

Table 1: Codes, Standards, and Regulatory Documents Referenced in Bruce A and B PROL and LCH.....	6
Table 2: Regulatory Documents.....	10
Table 3: CSA Standards .....	10
Table 4: International Standards .....	11
Table 5: Other Applicable Codes and Standards.....	12
Table 6: Key Implementing Documents.....	13

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


## List of Figures

Figure 1: Historical Dose to Public Trend .....	24
Figure 2: Environmental Performance Index .....	39

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


## Acronyms and Abbreviations

<b>AL</b>	Action Level
<b>ALARA</b>	As Low As Reasonably Achievable
<b>BP</b>	Bruce Power
<b>CALA</b>	Canadian Association for Laboratory Accreditation
<b>CANDU</b>	CANada Deuterium Uranium
<b>CFAM</b>	Corporate Functional Area Manager
<b>CNSC</b>	Canadian Nuclear Safety Commission
<b>COG</b>	CANDU Owners Group
<b>CSA</b>	Canadian Standards Association
<b>CV</b>	Confirm Validity
<b>DRL</b>	Derived Release Limit
<b>EAL</b>	Environmental Action Level
<b>EFADS</b>	Emergency Filter Air Discharge System
<b>EIW</b>	Environmental Impact Worksheet
<b>EMP</b>	Environmental Monitoring Program
<b>EMS</b>	Environmental Management System
<b>EPI</b>	Environmental Performance Index
<b>ERA</b>	Environmental Risk Assessment
<b>FASA</b>	Focused Area Self Assessment
<b>HEPA</b>	High Efficiency Particulate Air
<b>IAEA</b>	International Atomic Energy Agency
<b>IFB</b>	Irradiated Fuel Bay
<b>IIL</b>	Internal Investigation Level
<b>ISO</b>	International Organization for Standardization
<b>ISR</b>	Integrated Safety Review
<b>LCH</b>	Licence Conditions Handbook
<b>LTEP</b>	Long Term Energy Plan
<b>MCR</b>	Major Component Replacement
<b>MPER</b>	Maximum Probable Emission Rate

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

<b>NPP</b>	Nuclear Power Plant
<b>NSCA</b>	Nuclear Safety and Control Act
<b>OBT</b>	Organically-Bound Tritium
<b>OFI</b>	Opportunities for Improvements
<b>OPG</b>	Ontario Power Generation
<b>PROL</b>	Power Reactor Operating Licence
<b>PSR</b>	Periodic Safety Review
<b>QA</b>	Quality Assurance
<b>QC</b>	Quality Control
<b>RD/GD</b>	Regulatory Document/Guidance Document
<b>REMP</b>	Radiological Environmental Monitoring Program
<b>SBR</b>	Safety Basis Report
<b>SCA</b>	Safety and Control Area
<b>SCR</b>	Station Condition Record
<b>SEAs</b>	Significant Environmental Aspects
<b>SFR</b>	Safety Factor Report
<b>SSCs</b>	Structures, Systems and Components
<b>TAM</b>	Task Analysis Meeting



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## 1. Objective and Description

Bruce Power (BP), as an essential part of its operating strategy, is planning to continue operation of Bruce B as part of its contribution to the Long Term Energy Plan (LTEP) (<http://www.energy.gov.on.ca/en/ltep/>). Bruce Power has developed integrated plant life management plans in support of operation to 247,000 Equivalent Full Power Hours in accordance with the Bruce Power Reactor Operating Licence (PROL) [1] and Licence Conditions Handbook (LCH) [2]. A more intensive Asset Management program is under development, which includes a Major Component Replacement (MCR) approach to replacing pressure tubes, feeders and steam generators, so that the units are maintained in a fit for service state over their lifetime. However, due to the unusually long outage and de-fuelled state during pressure tube replacement, there is an opportunity to conduct other work, and some component replacements that could not be done reasonably in a regular maintenance outage will be scheduled concurrently with MCR. In accordance with Licence Condition 15.2 of the PROL [1], Bruce Power is required to inform the Canadian Nuclear Safety Commission (CNSC) of any plan to refurbish a reactor or replace a major component at the nuclear facilities, and Bruce Power shall:

- (i) Prepare and conduct a periodic safety review;
- (ii) Implement and maintain a return-to-service plan; and
- (iii) Provide periodic updates on progress and proposed changes.


The fifteen reports prepared as part of the Periodic Safety Review (PSR), including this Safety Factor Report (SFR), are intended to satisfy Licence Condition 15.2 (i) as a comprehensive evaluation of the design, condition and operation of the nuclear power plant (NPP). In accordance with Regulatory Document REGDOC-2.3.3 [3], a PSR is an effective way to obtain an overall view of actual plant safety and the quality of safety documentation and determine reasonable and practicable improvements to ensure safety until the next PSR.

Bruce Power has well-established PSR requirements and processes for the conduct of a PSR for the purpose of life-cycle management, which are documented in the procedure Periodic Safety Reviews [4]. This procedure, in combination with the Bruce B Periodic Safety Review Basis Document [5], governs the conduct of the PSR and facilitates its regulatory review to ensure that Bruce Power and the CNSC have the same expectations for scope, methodology and outcome of the PSR.

This PSR supersedes the Bruce B portion of the interim PSR that was conducted in support of the ongoing operation of the Bruce A and Bruce B units until 2019 [6]. Per REGDOC-2.3.3 [3], subsequent PSRs will focus on changes in requirements, facility conditions, operating experience and new information rather than repeating activities of previous reviews.

### 1.1. Objective

The overall objectives of the Bruce B PSR are to conduct a review of Bruce B against modern codes and standards and international safety expectations, and to provide input to a practicable

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

set of improvements to be conducted during the MCR in Units 5 to 8, and during asset management activities to support ongoing operation of all four units, as well as UOB, that will enhance safety to support long term operation. It will cover a 10-year period, since there is an expectation that a PSR will be performed on approximately a 10-year cycle, given that all units are expected to be operated well into the future.

The specific objective of the review of this Safety Factor is to determine whether the operating organization has an adequate program for surveillance of the radiological impact of the plant on the environment, which ensures that emissions are properly controlled and are as low as reasonably achievable (ALARA).


## 1.2. Description

The review is conducted in accordance with the Bruce B PSR Basis Document [5], which states that the review tasks are as follows:

Verification whether the monitoring program (that provides data on the radiological impact of the nuclear power plant on its surroundings) is appropriate and sufficiently comprehensive. In particular, the review should verify that the radiological impact of the plant on the environment is not significant compared with that due to other sources of radiation. (In this review task, “monitoring program” refers to both the effluent monitoring program and the environmental monitoring program.)

Additionally, as part of this review it should be verified that:

1. Concentrations of radionuclides in air, water (including river water, sea water and groundwater), soil, agricultural and marine products and animals are being monitored by the operating organization or by an independent public organization and are trended, and appropriate corrective actions are taken in the event that action levels are exceeded;
2. Potential new sources of radiological impact have been recognized by the operating organization;
3. Sampling and measurement methods are consistent with current standards;
4. Records of discharges of effluents are being monitored and trended and appropriate actions are taken to remain within established limits and to keep such discharges as low as reasonably achievable;
5. On-site monitoring is undertaken at locations and using methods that have a high probability of the prompt detection of a release of radioactive material to the environment;
6. Off-site monitoring for contamination levels and radiation levels is adequate and corrective actions are taken to keep such levels as low as reasonably achievable;
7. Actions have been taken to clean up contamination where reasonable and practicable;
8. Alarm systems to respond to unplanned releases of radioactive material from on-site facilities are suitably designed and available and will remain available in the future;
9. Appropriate data have been published on the environmental impact of the plant; and

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

10. Changes in the use of areas around the site have been taken into account in the development of monitoring programs.

As required by the PSR Basis Document, preparation of this Safety Factor Report included an assessment of the review tasks to determine if modifications were appropriate. Any changes to the review tasks described in this section are documented and justified in Section 5.

## 2. Methodology of Review


As discussed in the Bruce B PSR Basis Document [5], the methodology for a PSR should include making use of safety reviews that have already been performed for other reasons. Accordingly, the Bruce B PSR makes use of previous reviews that were conducted for the following purposes:

- Return to service of Bruce Units 3 and 4 (circa 2001) [7];
- Life extension of Bruce Units 1 and 2 (circa 2006) [8] [9] [10];
- Proposed refurbishments of Bruce Units 3 and 4 (circa 2008) [11] [12] [13] [14] [15];
- Safety Basis Report (SBR) and PSR for Bruce Units 1 to 8 (2013) [6]; and
- Bruce A Integrated Safety Review (ISR) to enhance safety and support long term operation (2015) [16] [17].

These reviews covered many, if not all, of the same Safety Factors that are reviewed in the current PSR. A full chronology of Bruce Power safety reviews up to 2013 is provided in Appendix F of [18].

The Bruce B PSR Safety Factor review process comprises the following steps:

1. **Interpret and confirm review tasks:** As a first step in the Safety Factor review, the Safety Factor Report author(s) confirm the review tasks identified in the PSR Basis Document [5] and repeated in Section 1.2 to ensure a common understanding of the intent and scope of each task. In some cases, this may lead to elaboration of the review tasks to ensure that the focus is precise and specific. Any changes to the review tasks are identified in Section 5 of the Safety Factor Report (SFR) and a rationale provided.
2. **Confirm the codes and standards to be considered for assessment:** The Safety Factor Report author(s) validates the list of codes and standards presented in the PSR Basis Document against the defined review tasks to ensure that the assessment of each standard will yield sufficient information to complete the review tasks. Additional codes and standards are added if deemed necessary. If no standard can be found that covers the review task, the assessor may have to identify criteria on which the assessment of the review task will be based. The final list of codes and standards considered for this Safety Factor is provided in Section 3.
3. **Determine the type and scope of assessment to be performed:** This step involves the assessor confirming that the assessment type identified in Appendix C of the Bruce B PSR Basis Document [5] for each of the codes, standards and guidance documents selected for


	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

this factor is appropriate based on the guidance provided. The PSR Basis Document provides an initial assignment for the assessment type, selecting one of the following review types:

- Programmatic Clause-by-Clause Assessments;
- Plant Clause-by-Clause Assessments;
- High-Level Programmatic Assessments;
- High-Level Plant Assessments;
- Code-to-Code Assessments; or
- Confirm Validity of Previous Assessment.

The final assessment types are identified in Section 3, along with the rationale for any changes relative to the assignment types listed in the PSR Basis Document.

4. **Perform gap assessment against codes and standards:** This step comprises the actual assessment of the Bruce Power programs and the Bruce B plant against the identified codes and standards. In general, this involves determining from available design or programmatic documentation whether the plant or program meet the provisions of the specific clause of the standard or of some other criterion, such as a summary of related clauses. Each individual deviation from the provisions of codes and standards is referred to as a Safety Factor “micro-gap”. The assessments, performed in Appendix A and Appendix B, include the assessor’s arguments conveying reasons why the clause is considered to be met or not met, while citing appropriate references that support this contention.
5. **Assess alignment with the provisions of the review tasks:** The results of the assessment against codes and standards are interpreted in the context of the review tasks of the Safety Factor. To this end, each assessment, whether clause-by-clause, high-level or code-to-code, is assigned to one or more of the review tasks (Section 5). Assessment against the provision of the review task involves formulating a summary assessment of the degree to which the plant or program meets the objective and provisions of the particular review task. This assessment may involve consolidation and interpretation of the various compliance assessments to arrive at a single compliance indicator for the objective of the review task as a whole. The results of this step are documented in Section 5 of each SFR.
6. **Perform program assessments:** The most pertinent self-assessments, audits and regulatory evaluations are assessed, and performance indicators relevant to the Safety Factor identified. The former illustrates that Bruce Power has a comprehensive process of reviewing compliance with Bruce Power processes, identifying gaps, committing to corrective actions, and following up to confirm completion and effectiveness of these actions. The latter demonstrates that there is a metric by which Bruce Power assesses the effectiveness of the programs relevant to the Safety Factor in Section 7. Taken as a whole, these demonstrate that the processes associated with this Safety Factor are implemented effectively (individual findings notwithstanding). Thus, program effectiveness, if not demonstrated explicitly in the review task assessments in Step 5, can be inferred if Step 5

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

shows that Bruce Power processes meet the Safety Factor requirements and if this step shows there are ongoing processes to ensure compliance with Bruce Power processes.

7. **Identification of findings:** This step involves the consolidation of the findings of the assessment against codes and standards and the results of executing the review tasks into a number of definitive statements regarding positive and negative findings of the assessment of the Safety Factor. Positive findings or strengths are only identified if there is clear evidence that the Bruce B plant or programs exceed compliance with the provision of codes and standards or review task objectives. Each individual negative finding or deviation is designated as a Safety Factor micro-gap for tracking purposes. Identical or similar micro-gaps are consolidated into comprehensive statements that describe the deviation known as Safety Factor macro-gaps, which are listed in Section 8 of the Safety Factor Reports, as applicable.

### 3. Applicable Codes and Standards

This section lists the applicable regulatory requirements, codes and standards considered in the review of this Safety Factor. Table C-1 of the Bruce B PSR Basis Document [5] identifies the codes, standards and guides that are relevant to this PSR. Modern revisions of some codes and standards listed in Table C-1 of the PSR Basis Document [5] have been identified in the licence renewal application and supplementary submissions for the current PROL [19] [20] [21]. Codes, standards and guides issued after the freeze date of December 31, 2015 were not considered in the review [5].

#### 3.1. Acts and Regulations


The *Nuclear Safety and Control Act* (NSCA) [22] establishes the Canadian Nuclear Safety Commission and its authority to regulate nuclear activities in Canada. Bruce Power has a process to ensure compliance with the NSCA [22] and its Regulations. Therefore, the NSCA and its Regulations were not considered further in this review.

#### 3.2. Power Reactor Operating Licence

The list of codes and standards related to radiological impact on the environment that are referenced in the PROL [1] and LCH [2] noted in Table C-1 of the Bruce B, PSR Basis Document [5] are identified in Table 1. The edition dates referenced in the third column of the table are the modern versions used for comparison.

The PROL contains five licence conditions that are directly relevant to this review:

- “G.2 The licensee shall give written notification of changes to the facilities or their operation, including deviation from design, operating conditions, policies, programs and methods referred to in the licensing basis.”
- “G.5 The licensee shall implement and maintain a public information and disclosure program.”

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


- “3.3 The licensee shall notify and report in accordance with CNSC regulatory document REGDOC-3.1.1 REPORTING REQUIREMENTS: NUCLEAR POWER PLANTS.”
- “9.1 The licensee shall implement and maintain an environmental protection program and undertake specific measures to control releases of nuclear and hazardous substances in accordance with applicable limits and to monitor effluents.
- “9.2 The licensee shall have a set of environmental action levels for nuclear substances. When the licensee becomes aware that an environmental action level has been reached, the licensee shall notify the Commission within seven days.”

The LCH provides details on compliance with these licence conditions, and refers to relevant regulatory documents and standards.

**Table 1: Codes, Standards, and Regulatory Documents Referenced in Bruce A and B PROL and LCH**

Document Number	Document Title	Modern Version Used for PSR Comparison	Type of Review
CNSC G-129 (2004)	Keeping Radiation Exposures and Doses 'As Low As Reasonably Achievable (ALARA)'	[23]	HL
CNSC G-228 (2001)	Developing and Using Action Levels	[24]	HL
CNSC RD/GD-99.3 (2012)	Public Information and Disclosure	[25]	NA
CNSC REGDOC-2.3.3 (2015)	Periodic Safety Reviews	[3]	NA
CNSC REGDOC-2.9.1 (2013)	Environmental Protection, Policies, Programs and Procedures at Class I Nuclear Facilities and Uranium Mines and Mills	[26]	NA
CNSC REGDOC-3.1.1 (2014)	Reporting Requirements for Operating Nuclear Power Plants	[27]	NA
CSA N286-05 [28]	Management system requirements for nuclear power plants	CSA N286-12 [29]	NA



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Document Number	Document Title	Modern Version Used for PSR Comparison	Type of Review
CSA N288.1-14	Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities	[30]	HL
CSA N288.4-10	Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills	[31]	HL
CSA N288.5-11	Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills	[32]	HL
CSA N288.6-12	Environmental risk assessments at Class I nuclear facilities and uranium mines and mills	[33]	HL
CSA N292.3-14	Management of low- and intermediate-level radioactive waste	[34]	2SF


Assessment type:

**NA:** Not Assessed; **CBC:** Clause-by-Clause; **PCBC:** Partial Clause-by-Clause; **CTC:** Code-to-Code;  
**HL:** High Level; **2SF:** Assessment performed in another SFR; **CV:** Confirm Validity of Previous Assessments

**CNSC G-129:** Table C-1 of the PSR Basis Document [5] identifies CNSC Regulatory Guide G-129 as requiring a high-level review under SF14. Discussion of Licence Condition 7.1 in the LCH [2] notes that G-129 “provides the licensee guidance for developing, implementing and maintaining a radiation protection program to ensure exposures will be ALARA.” While G-129 applies primarily to radiation protection of workers, some clauses are applicable to environmental releases and so it is included here. A high-level assessment of the document is given in Appendix A (A.6).

**CNSC G-228:** Table C-1 of the PSR Basis Document [5] identifies CNSC Regulatory Guide G-228 as requiring a high-level review under SF14. Discussion of Licence Condition 9.2 in the LCH [2] lists Environmental Action Levels (EALs) and notes that, “CNSC staff use the criteria set out in CNSC guidance document G-228, Developing and Using Action Levels, as guidance to help assess the adequacy of EALs established by the licensee. The licensee should review and, if necessary revise the EALs specified above at least once per licence period in order to validate their effectiveness.” A high-level assessment of G-228 is included in Appendix A (A.8).

**CNSC RD/GD-99.3:** Table C-1 of the PSR Basis Document [5] shows that RD/GD-99.3 is included in the current licence and accordingly no further assessment is performed for this PSR.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

**CNSC REGDOC-2.3.3:** This PSR is being conducted in accordance with CNSC REGDOC-2.3.3 per PROL Licence Condition 15.2 (i) [1] and associated compliance verification criteria [2]. Therefore, REGDOC-2.3.3 is not reviewed further in this document.

**CNSC REGDOC-2.9.1:** Table C-1 of the PSR Basis Document [5] calls for a code-to-code comparison of CNSC REGDOC-2.9.1 to its predecessor documents S-296 [35] and G-296 [36], and for a high-level review. However, REGDOC-2.9.1 is now included in the LCH under Licence Condition 9.1, with an implementation strategy leading to full compliance by December 31, 2018. Since the CNSC has approved the transition plan and stated that no additional measures are necessary [2], REGDOC-2.9.1 is not further assessed in this document.


**CNSC REGDOC-3.1.1:** Table C-1 of the PSR Basis Document [5] does not call for review of CNSC REGDOC-3.1.1. Compliance with this regulatory document is explicitly required under PROL Licence Condition 3.3 (see Section 3.2), and therefore an assessment is not required.

**CSA N286-12:** CSA N286-05 is noted in the PROL (Licence Condition 1.1 [1]). Per the LCH [2], an implementation strategy for the 2012 version is in progress to be submitted to the CNSC by the end of January 2016. CNSC staff have stated that in their view the CSA N286-12 version of CSA N286 “does not represent a fundamental change to the current Bruce Power Management System” and have acknowledged that “the new requirements in CSA N286-12 are already addressed in Bruce Power’s program and procedure documentation” [37].

Bruce Power had agreed to perform a gap analysis and to prepare a detailed transition plan, and to subsequently implement the necessary changes in moving from the CSA N286-05 version of the code to the CSA N286-12 version, during the current licensing period [38]. This timeframe will facilitate the implementation of N286 changes to the management system, and enable the gap analysis results from the large number of new or revised Regulatory Documents or Standards committed in the 2015 operating licence renewal. Bruce Power has also proposed that in the interim, CSA N286-05 be retained in the PROL to enable it to plan the transition to CSA N286-12, and committed to develop the transition plan and communicate the plan to the CNSC by January 30, 2016 [39]. Bruce Power further stated CSA N286-12 does not establish any significant or immediate new safety requirements that would merit a more accelerated implementation. The gap analysis and the resulting transition plan were submitted to the CNSC [40]. Per [40], the major milestones of the transition plan to N286-12 are as follows:

- 22 January 2016: Discuss all the regulatory actions and the transition plan at the Corporate Functional Area Manager (CFAM) meeting
- 31 December 2016: Revision of CFAM Program Document(s) [with LCH notification requirements to the CNSC] to comply with CSA N286-12 requirements completed
- 31 March 2017: Revision of CFAM Program Document(s) [that do not have LCH notification requirements to the CNSC] to comply with CSA N286-12 requirements completed
- 31 December 2017: Confirmation that that all impacted documents in the program suite comply with the requirements of CSA N286-12



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- 15 September 2018: Verification via a Focused Area Self Assessment (FASA) that previously identified transition Gaps to meeting the requirements of CSA N286-12 have been addressed and effectively implemented
- 14 December 2018: issue notification to the CNSC regarding state of CSA N286-12 readiness, and, implementation date

This Safety Factor therefore has not performed a code-to-code assessment between CSA N286-05 and CSA N286-12 and will not be performing a clause-by-clause assessment of CSA N286-05, since it is in the current licence and there is a transition plan in effect.

**CSA N288.1-14:** Table C-1 of the PSR Basis Document [5] calls for a high-level assessment of this standard. CSA N288.1 [30] provides guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities. A high-level assessment is provided in Appendix A (A.1).


**CSA N288.4-10:** Table C-1 of the PSR Basis Document [5] calls for a high-level assessment of this standard, which was reaffirmed in 2015. CSA N288.4 [31] addresses the design and operation of environmental monitoring programs (EMPs) at Class I nuclear facilities and uranium mines and mills, and is currently in the process of being implemented at Bruce Power. It has been reviewed only with respect to progress towards Bruce Power's implementation. A high-level assessment is provided in Appendix A (A.2).

**CSA N288.5-11:** Table C-1 of the PSR Basis Document [5] calls for a high-level assessment of this standard. CSA N288.5 [32] addresses the design and operation of effluent monitoring programs for Class I nuclear facilities and uranium mines and mills. CSA N288.5-11 is currently in the process of being implemented at Bruce Power, and so has been reviewed only with respect to progress towards its implementation. A high-level assessment is provided in Appendix A (A.3).

**CSA N288.6-12:** Table C-1 of the PSR Basis Document [5] calls for a high-level assessment of this standard. CSA N288.6-12 [33] addresses the design, implementation and management of environmental risk assessments for nuclear facilities and uranium mines and mills. CSA N288.6-12 is currently in the process of being implemented at Bruce Power, and so has been reviewed only with respect to progress towards its implementation. The review is provided in Appendix A (A.4).

**NOTE:** Since CSA Standards N288.4-10, N288.5-11 and N288.6-12 are all now referenced in the LCH [2] along with effective dates, assessments are not strictly necessary. However, high-level assessments have been carried over from the Bruce A Safety Factor Report 14 [17] to the present report for consistency.

**CSA N292.3-14:** Table C-1 of the PSR Basis Document [5] shows this standard as subject to a clause-by-clause assessment under Safety Factor 11: Procedures. Since there are no clauses in this standard that are specifically related to the review tasks of Safety Factor 14, no assessment will be performed in this report.

 <div>Division of Kinectrics Inc.</div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

### 3.3. Regulatory Documents

The Regulatory Document in Table 2 was in addition to those identified in Table 1 and was considered for application to the review tasks of this Safety Factor.

**Table 2: Regulatory Documents**

Document Number	Document Title	Reference	Type of Review
CNSC RD-346	Site Evaluation for New Nuclear Power Plants	[41]	NA
Assessment type: <b>NA:</b> Not Assessed; <b>CBC:</b> Clause-by-Clause; <b>PCBC:</b> Partial Clause-by-Clause; <b>CTC:</b> Code-to-Code; <b>HL:</b> High Level; <b>2SF:</b> Assessment performed in another SFR; <b>CV:</b> Confirm Validity of Previous Assessments			


**CNSC RD-346:** Table C-1 of the PSR Basis Document [5] calls for a CV review of this regulatory document. CNSC RD-346 represents the CNSC staff's adoption, or where applicable, adaptation of the principles set forth by the International Atomic Energy Agency (IAEA) in NS-R-3 Site Evaluation for Nuclear Installations [42]. The IAEA guides under NS-R-3 relate to siting, which has been fully addressed as part of the Environmental Assessment conducted for Bruce B in 2004 [43]. The same argument applies to CNSC RD-346. Therefore, CNSC RD-346 is not assessed for this Safety Factor.

### 3.4. CSA Standards

In addition to those identified in the Bruce Power PROL [1] and LCH [2], the Canadian Standards Association (CSA) standards identified in Table C-1 of the PSR Basis Document [5] considered for application to review tasks of this Safety Factor are included in Table 3.

**Table 3: CSA Standards**

Document Number	Document Title	Reference	Type of Review
CSA N288.3.4-13	Performance testing of nuclear air cleaning systems at nuclear facilities	[44]	HL
CSA N288.7-15	Groundwater protection programs at Class I nuclear facilities and uranium mines and mills	[45]	HL
Assessment type: <b>NA:</b> Not Assessed; <b>CBC:</b> Clause-by-Clause; <b>PCBC:</b> Partial Clause-by-Clause; <b>CTC:</b> Code-to-Code; <b>HL:</b> High Level; <b>2SF:</b> Assessment performed in another SFR; <b>CV:</b> Confirm Validity of Previous Assessments			

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

**CSA N288.3.4-13:** Table C-1 of the PSR Basis Document [5] identifies this standard as requiring a high-level assessment. CSA N288.3.4 sets requirements and provides guidance for the performance testing of air-cleaning systems at nuclear facilities. Its scope is limited to systems that remove radioactive particulate matter and iodine species from airborne effluent streams. A high-level assessment is provided in Appendix A (A.9).

**CSA N288.7-15:** Table C-1 of the PSR Basis Document [5] did not identify this standard. However, it provides guidance on establishing and operating a groundwater protection program, which is relevant to the review task described in Section 5.2. A high-level assessment is provided in Appendix A (A.10).

### 3.5. International Standards


The international standards listed in Table 4 are relevant to this Safety Factor and were considered for this review.

**Table 4: International Standards**

Document Number	Document Title	Reference	Type of Review
IAEA NS-G-3.2 (2002)	Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants	[46]	HL
IAEA SSG-25 (2013)	Periodic Safety Review for Nuclear Power Plants	[47]	NA
Assessment type: <b>NA:</b> Not Assessed; <b>CBC:</b> Clause-by-Clause; <b>PCBC:</b> Partial Clause-by-Clause; <b>CTC:</b> Code-to-Code; <b>HL:</b> High Level; <b>2SF:</b> Assessment performed in another SFR; <b>CV:</b> Confirm Validity of Previous Assessments			

**IAEA NS-G-3.2:** Table C-1 of the PSR Basis Document [5] identifies this IAEA safety guide as requiring a high-level assessment; this is provided in Appendix A (A.5).

**IAEA SSG-25:** IAEA SSG-25 [47] addresses the periodic safety review of nuclear power plants. Per the PSR Basis Document [5], this PSR is being conducted in accordance with REGDOC-2.3.3. As stated in REGDOC-2.3.3 [3], this regulatory document is consistent with IAEA SSG-25. The combination of IAEA SSG-25 and REGDOC-2.3.3, define the review tasks that should be considered for the Safety Factor Reports. However, no assessment is performed specifically on IAEA SSG-25.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

### 3.6. Other Applicable Codes and Standards

One additional standard was considered for application to review tasks of this Safety Factor and is listed in Table 5.

**Table 5: Other Applicable Codes and Standards**

Document Number	Document Title	Reference	Type of Review
ANSI/HPS N13.1-2011	Sampling and Monitoring Releases of Airborne Radioactive Substances From the Stacks and Duct of Nuclear Facilities	[48]	HL
Assessment type: <b>NA:</b> Not Assessed; <b>CBC:</b> Clause-by-Clause; <b>PCBC:</b> Partial Clause-by-Clause; <b>CTC:</b> Code-to-Code; <b>HL:</b> High Level; <b>2SF:</b> Assessment performed in another SFR; <b>CV:</b> Confirm Validity of Previous Assessments			


**ANSI/HPS N13.1:** Table C-1 of the PSR Basis Document [5] identified this standard as requiring a high-level review. ANSI/HPS N13.1-2011 provides guidance on automatic alarms for airborne radioactive releases. A high-level assessment is provided in Appendix A (A.7).

## 4. Overview of Applicable Bruce B Station Programs and Processes

This section provides a brief overview of the key Bruce Power programs, procedures and practices related to this Safety Factor.

### 4.1. Level 0 Document

Bruce Power's Management System, BP-MSM-1 [49], provides the overall framework for integration of safety, environment, quality, economic and other requirements. With respect to the management of environmental safety, Bruce Power has implemented an Environmental Safety Management Program, BP-PROG-00.02 [50], which meets the requirements of an environmental management system (EMS) as required by ISO 14001:2004 [51]. BP-PROG-00.02 defines the overall scope, business need, functional requirements, constituent elements and key responsibilities associated with the management of environmental safety.


	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

BP-PROG-00.02 takes its authority from BP-MSM-1, which expresses Bruce Power's policy on environmental management. The key implementing documents are listed in Table 6.<sup>1</sup>

**Table 6: Key Implementing Documents**

Level 0	Level 1	Level 2	Level 3
BP-MSM-1: Management System Manual [49]	BP-PROG-00.02: Environmental Safety Management [50]	BP-PROC-00076: Management of the Off- Site Radiological Environmental Monitoring Program [52]	
		BP-PROC-00080: Effluent Monitoring Program [53]	BP-PROC-00171: Radiological Emissions Monitoring: Limits, Action Levels [54]
			NK29-REP-03482- 00003: Derived Release Limits and Action Levels for Bruce Nuclear Generating Station B [55]
		BP-PROC-00793: Environmental Performance Index Indicators and Reporting Procedure [56]	
		DPT-ENV-00016: Environmental Risk Assessment - Aspect/Impact [57]	

<sup>1</sup> Table 6 lists the key governance documents used to support the assessments of the review tasks for this Safety Factor Report. A full set of current sub-level documents is provided within each current PROG document. In the list of references, the revision number for the governance documents is the key, unambiguous identifier; the date shown is an indicator of when the document was last updated, and is taken either from PassPort, the header field, or the "Master Created" date in the footer.

 <div style="font-size: small;">Division of Kinectrics Inc.</div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Level 0	Level 1	Level 2	Level 3
		BP-PROC-00870: Spills Management and Contaminated Lands Program [58]	BP-PROC-00241: Management of Soil and Groundwater Contamination [59]

#### 4.2. Level 1 Document

According to Section 1.0 of BP-PROG-00.02, Environmental Safety Management,


“The purpose of the Environmental Safety Management Program is to define the requirements and elements of environmental protection and to oversee the planning, implementation and control of activities associated with minimizing potential adverse impacts of Bruce Power operations on the natural environment. The Bruce Power Environmental Safety Management Program conforms to the Canadian Nuclear Safety Commission (CNSC) regulatory standards S-296, Canadian Standards Association (CSA) N286-05 (2007), Clauses 6.28 and 6.29 as well as the International Organization for Standardization (ISO) 14001 for Environmental Management Systems. Programs, processes, and procedures will, at a minimum, assure compliance with regulatory and statutory requirements and facilitate continual improvement in environmental performance.” [50]

BP-PROG-00.02 describes:

- Establishing, implementing and maintaining the requirements of an EMS per ISO 14001:2004 [51];
- Bruce Power’s approach to ensure compliance with S-296 [35]; and
- Bruce Power’s approach to ensuring compliance with all applicable statutory, regulatory and other requirements.

These two reference documents have recently been revised or replaced. The standard ISO 14001:2004 [51] has been revised to ISO 14001:2015 [60], and there are significant changes to its structure and content. The CNSC regulatory standard S-296 [35] has been replaced by REGDOC-2.9.1 [26], as described in Section 3.2. (This discrepancy in reference to the applicable CNSC document has been referred to Safety Factor 10: Organization and Administration as an example of a generic gap related to governance documents.) REGDOC-2.9.1 is referenced in the LCH and requires licensees to meet the requirements of ISO 14001:2004 [51]. However, compliance with the requirements of the 2015 revision of the standard will be required to maintain ISO certification, as described in the “Quick Hit” Self-Assessment SA-ENV-2015-02 [61] (see Section 7.1).

Section 4 and Appendix C of BP-PROG-00.02 [50] map the programs and procedures that form the Bruce Power EMS onto the required elements of an EMS as set out in ISO 14001:2004 [51]. Section 4.7 of BP-PROG-00.02 addresses EMS supporting programs, as required by CSA

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

N286-05 [28]. The sections of BP-PROG-00.02 that are most directly relevant to the scope of this review are:

- Section 4.5.1, Monitoring and Measurements,
- Section 4.5.3, Nonconformance and Corrective Action and Preventive Action,
- Section 4.5.4, Control of Records,
- Section 4.7.1, Emissions Management,
- Section 4.7.3, Land Assessment and Remediation Management, and
- Section 4.7.7, Environmental Impacts Management.

### 4.3. Level 2 Documents


BP-PROG-00.02 identifies four Level 2 documents that are directly relevant to this review, as described in the following.

BP-PROC-00076, Management of the Off-Site Radiological Environmental Monitoring Program [52] describes Bruce Power's Radiological Environmental Monitoring Program (REMP), which is designed to meet the requirements of CSA N288.4-10, Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills [31]. Bruce Power's REMP provides the following:

- Data to estimate actual or potential doses to critical groups and populations from the presence of radiation fields or radioactive materials in the environment as a result of operations on the Bruce Power site.
- Data to confirm compliance of the facility or source with release guidelines and regulations and to provide public assurance of compliance.
- A check, independent of effluent monitoring, on the effectiveness of containment and effluent control.
- A database to facilitate the detection of trends.
- Verification or refinement of the predictions of environmental models.
- Determination of the fate of released radioactive materials to show whether any significant pathway to man has been overlooked.

BP-PROC-00080, Effluent Monitoring Program [53], describes Bruce Power's Effluent Monitoring Program, provides information on the design, implementation, and management of an effluent monitoring program that meets legal and business requirements and incorporates current best practices and technologies used internationally. This procedure also describes specific details on the airborne and liquid effluents monitoring program under normal and abnormal operating conditions. The current revision of the program (R006) is designed to meet the requirements of CSA N288.5-11 [32].



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

BP-PROC-00793, Environmental Performance Index Indicators and Reporting Procedure [56], describes, in Section 1.0, “the requirements for producing the Environmental Performance Index (EPI) on a monthly basis. The EPI is a report card using environmental events and regulatory infractions as a means to monitor and measure environmental performance.”

DPT-ENV-00016, Environmental Risk Assessment – Aspect/Impact [57], outlines the methodology for identifying and determining the significance of Environmental Aspects, environmental risks, environmental impacts and environmental flagging of equipment at Bruce Power. Environmental Aspects are identified and ranked in order to ensure that those aspects that have, or can have, a significant impact on the environment are managed to achieve the desired environmental performance. Identification of Environmental Aspects, their associated environmental impacts, and those Environmental Aspects that are determined to be Significant Environmental Aspects (SEAs) is a fundamental part of an EMS under ISO 14001:2004 [51] and CNSC Regulatory Document REGDOC-2.9.1 [26]. The current revision of this procedure (R006) is designed to meet the requirements of ISO 14001:2004 and REGDOC-2.9.1.

BP-PROC-00870, Spill Management and Contaminated Lands Program [58], outlines “the steps and procedures necessary to meet the requirements and objectives of the Spill Management and Contaminated Lands Program which satisfies the requirements of Ontario Regulation 224/07, Spill Prevent and Contingency Plans made under the Environmental Protection Act. ... The objective for the Spill and Contaminated Lands Program is to align all facilities with respect to regulatory compliance, prevention and mitigation of spills and spill risks, spill response and remediation measures to ensure consistency is achieved across site and to ensure that the environmental impact of spills is as low as reasonably possible.”

Additional Level 2 and lower-level documents related to this Safety Factor are identified in BP-PROC-00076 [52], BP-PROC-00080 [53] and DPT-ENV-00016 [57].

#### **4.4. Level 3 Documents**


There are two Level 3 documents that are mentioned in the LCH. They are:

BP-PROC-00171, Radiological Emissions Monitoring: Limits, Action Levels [54], describes the process for calculating Derived Release Limits (DRLs), Action Levels (ALs) and related emission quantities. It lists the various emission limits and describes the actions to be taken when an emission limit is exceeded. It also describes the Bruce Power framework for control of radioactive emissions.

NK29-REP-03482-00003, Derived Release Limits and Action Levels for Bruce Nuclear Generating Station B [55], presents the calculations of DRLs and ALs, leading to the results given in BP-PROC-00171.

An additional Level 3 document relevant to this assessment is BP-PROC-00241, Management of Soil and Groundwater Contamination [59]. Its purpose is to “provide a framework by which Bruce Power can conduct the activities of environmental assessment, evaluation, remediation, restoration, sampling and non-routine monitoring of contaminated or potentially contaminated sites with respect to soil and groundwater quality.”



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## 5. Results of the Review Tasks

The results of the review of this Safety Factor are documented below under headings that correspond to the review tasks listed in Section 1.2 of this document. The review tasks assessed in this section have not changed from those listed in Section 1.2.

### 5.1. Appropriateness of Monitoring Program

The review task is to verify that:

The monitoring program is appropriate and sufficiently comprehensive. In particular, verify that the radiological impact of the plant on the environment is not significant compared with that due to other sources of radiation.

Licence Condition 9.1 requires that the licensee, “implement and maintain an environmental protection program and undertake specific measures to control releases of nuclear and hazardous substances in accordance with applicable limits and to monitor effluents” [1]. The LCH [2] includes CNSC REGDOC-2.9.1 [26] as one of the relevant documents requiring version control. REGDOC-2.9.1 requires that the licensee “Establish, implement and maintain an EMS that meets the requirements set by CSA ISO 14001:2004, *Environmental Management Systems—Requirements with Guidance for Use*” [51]. Conformance with this requirement is documented in the environmental program document BP-PROG-00.02 [50], and is demonstrated by Bruce Power being certified to the ISO standard. In the LCH, CNSC notes that,


“Bruce Power is in full compliance with all requirements of REGDOC 2.9.1, with two exceptions:

- 1) There is currently no industry “best practice” for the assessment of risks related to non-human biota and there are gaps in Bruce Power’s EMS in this regard. These gaps will be addressed with implementation of the N288 series.
- 2) Administrative documentation updates are required.

Consistent with the transition plan for the N288 series of standards, the foregoing actions are targeted for completion by December 31, 2018. No additional transition measures are required.”

CSA Standard N288.5-11, Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills [32], addresses the design and operation of effluent monitoring programs. Conformance to this standard is required under Licence Condition 9.1, with an effective date of December 31, 2018. Effluent monitoring is discussed further below in Sections 5.4, 5.5 and 5.6.

CSA Standard N288.4-10, Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills [31], provides guidance on the design and operation of an EMP. Conformance to this standard is required under Licence Condition 9.1, with an effective date of December 31, 2018.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Results of the EMP are published annually in a report that is submitted to the CNSC. The report includes data on trends of the annual calculated radiation doses to the most exposed members of the public due to release of radiation and radioactivity from the Bruce site (which includes Bruce A, Bruce B, Ontario Power Generation's Western Waste Management Facility, and Canadian Nuclear Laboratories' Douglas Point Waste Management Facility). According to the 2014 report [62], average annual doses to the public have been lower in the last four years (2011-2014) than in the previous ten years (2001-2010). In that more recent time period, annual doses have not exceeded 0.2% of the public dose limit of 1000  $\mu\text{Sv}/\text{year}$ , and have been less than 0.1% of the typical natural background dose of about 2100  $\mu\text{Sv}/\text{year}$ . Ontario Power Generation (OPG) operates a background radiological monitoring program and provides the resulting data to Bruce Power for inclusion in the annual report.

It is concluded that Bruce Power meets the requirements of this review task.

## 5.2. Concentrations of Radionuclides and Corrective Actions

The review task is to verify that:

Concentrations of radionuclides in air, water (including river water, sea water and groundwater), soil, agricultural and marine products and animals are being monitored by the operating organization or by an independent public organization and are trended, and appropriate corrective actions are taken in the event that action levels are exceeded.


PROL Conditions 9.1 and 9.2 require monitoring and control of radiological releases to the environment, and notification of the CNSC within seven days of an AL being exceeded. Detailed requirements for environmental monitoring are given in CSA Standard N288.4-10 [31]

According to CNSC Regulatory Guide G-228 [24], Section 8.0, when an AL is reached an investigation should be conducted to determine the cause, identify and take action to restore the effectiveness of the radiation protection program and notify the CNSC within the time period specified in the licence. These actions should be appropriate to the circumstances and commensurate with the level of risk associated with reaching the AL.

The recently-issued standard CSA N288.7-15 [45] establishes requirements and provides guidance for a groundwater protection program, which includes a groundwater monitoring program. There is no regulatory requirement to comply with the requirements of this standard at present, but it could be incorporated into future regulatory documents or licence conditions.

According to BP-PROC-00076 [52], the media that are being monitored for radionuclide concentrations are air, water (drinking, surface, well, precipitation, ground), agricultural plants (fruits, vegetables, grains), animal products (meat, milk, honey), fish, sediment and soil. The results are published in the annual Environmental Monitoring Program Report, and compared with historical trends. The 2014 report is Reference [62].

Bruce Power's groundwater monitoring program is described in BP-PROC-00241, Management of Soil and Groundwater Contamination [59]. This document also describes the performance of an environmental site assessment and the development of a conceptual site model, but it does

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

not establish any ALs. The development of a groundwater protection program to comply with CSA N288.7-15 is in progress (see the discussion of FASA SA-ENV-2014-01 in Section 7.1).

The calculation of ALs and the response required when one is exceeded are described in BP-PROC-00171 [54]. A review of the action tracking database for CNSC-reportable events showed that no AL for effluent or environmental release has been exceeded in the last five years, and consequently no corrective actions have been needed.

Section 5.8 also describes the actions to be taken if an AL is exceeded, but further states that no ALs related to environmental radiological releases have been exceeded in the last five years. It is concluded that Bruce Power meets the requirements of this review task.

### 5.3. Potential New Sources of Radiological Impact

The review task is to verify that:

Potential new sources of radiological impact have been recognized by the operating organization.


Section 5.3.1 of CSA Standard N288.4-10 [31] defines the types of change that may result in the need for a revised Environmental Risk Assessment (ERA) and a change to the EMP. This Standard goes on in Section 5.3.3 to require a periodic review of the EMP and in Section 5.3.4 to require revisions to the EMP where there has been a change in the environmental risks. In addition, CSA Standard N288.6-12 [33] requires in Section 11 that an ERA be reviewed “on a five-year cycle or more frequently if major facility changes are proposed that would trigger a predictive assessment...”

The process at Bruce Power for identifying radiological impacts (referred to as Environmental Aspects) is described in DPT-ENV-00016 [57]. There is a database that is used to track Environmental Aspects, which may be identified in a wide variety of ways, listed in Section 4.3 of the document.

The screening level (Tier 1) risk assessment required by N288.6-12 was completed in March 2013 [63]. A Tier 1 assessment applies screening criteria to identify environmental issues (receptors and stressors) that require further quantitative evaluation at a higher level (Tier 2 or Tier 3). However, radiological stressors require higher-level evaluation even though they meet the screening criteria, to satisfy CNSC reporting requirements and to address public concerns. The higher-level risk assessment was completed and issued in January 2015 [64].

A recent example of Bruce Power recognizing potential new (or additional) sources of radiological impact is a study that calculated the potential public dose due to routine releases of gaseous tritium (HT) [65]. The study concluded, in Section 6.0, that, “HT could be emitted from Units at Bruce A in negligible quantities, when compared to emission of HTO. Compared with public dose resulting from the total emissions from Bruce Power site, the dose to public due to the emission of gaseous tritium is expected to be four orders of magnitude less. Accordingly, HT emission does not require regular monitoring and the calculation of [DRL] for HT is not required.”

It is concluded that Bruce Power meets the requirements of this review task.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

#### 5.4. Sampling and Measurement Methods

The review task is to verify that:

Sampling and measurement methods are consistent with current standards.

For environmental sampling, this review task is explicitly addressed in only one of the codes and standards that were assessed for this Safety Factor. Section 8 of CSA Standard N288.7-15 [45] provides guidance on the sampling and analysis of ground water. For other sample types, Section 8.4 of CSA Standard N288.4-10 [31] is a list of references that provides guidance on environmental sampling and analysis techniques. For effluent sampling, guidance is provided in CSA Standard N288.5-11 [32]. All three of these standards are currently being implemented at Bruce Power.

The sampling and measurement procedures for radiological monitoring are referenced in B-PROC-00076 [52]. Most of the sampling and analyses are conducted by the Bruce Power Health Physics Laboratory, which has been accredited to the analytical laboratory standard ISO/IEC 17025 [66] by the Canadian Association for Laboratory Accreditation (CALA). The exception is environmental gamma-ray monitoring, which is performed with thermoluminescent dosimeters supplied and analyzed by the Ontario Power Generation Health Physics Laboratory. This laboratory is also accredited by CALA.

A recent audit [67] found some deficiencies in sampling and the reporting of results (see Section 7.2.1 for details.) These deficiencies are being corrected through three Action Requests (28456566, 28456570, and 28456573) and therefore this does not constitute a gap for the purpose of this assessment.


For effluent sampling and measurement, there is no corresponding list of procedures in either the program document, BP-PROC-00080 [53], or in the document Radionuclide Effluent Monitoring System Requirements, B-ST-03480-10000 [68]. The latter document states, in Table 5, that "Procedure for the calculations of emissions must be documented. (These are currently found in Chemistry Laboratory Procedures.)", but does not reference those procedures. A self-assessment of Chemistry Lab compliance with the requirements of ISO/IEC 17025 conducted at the end of 2013 (SA-CHEM-2013-01 [69]) identified a number of gaps. Actions are in progress to close them by the end of 2016, and therefore this does not constitute a gap for the purpose of this assessment (see Section 7.1 for details). However, there is currently no plan to seek ISO/IEC certification of the Bruce Power Chemistry Laboratories.

It is concluded that Bruce Power meets the requirements of this review task.

#### 5.5. Effluent Discharge Records: Monitoring, Trending and Responding

The review task is to verify that:

Records of discharges of effluents are being monitored and trended and appropriate actions are taken to remain within established limits and to keep such discharges as low as reasonably achievable.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

PROL Condition 9.1 requires that releases of nuclear substances to the environment be controlled and monitored, and the LCH elaborates on the development and use of DRLs to effect such control [2]. The CSA Standard N288.5-11 [32] provides guidance on the design and operation of effluent monitoring programs at Class I nuclear facilities. Bruce Power has committed to the full implementation of this standard by December 2018 [2], [70].

The Bruce Power effluent monitoring program and the requirements for recordkeeping are described in BP-PROC-00080 [53]. Results of effluent monitoring are reported in quarterly operations reports to the CNSC, as required by CNSC REGDOC-3.1.1 [27]. In addition, effluent monitoring results are included in the annual EMP Report.

Emission limits and ALs are given in BP-PROC-00171 [54]. The calculation of DRLs and ALs is described in NK29-REP-03482-00003 [55], which uses the methodology of CSA Standard N288.1-08, Update No. 1 [71] to calculate DRLs. There has been a recent revision of this standard, N288.1-14 [30], which updates some of the model parameters it prescribes for use in the calculations and refines some of the models. A high-level review of this standard is given in Appendix A.1. Bruce Power is participating in a CANDU Owners Group (COG) project to revise the DRL calculation program IMPACT to include the changes in N288.1-14, as described in COG Work Package# 30495 [72]. Once this is done, calculations will be based on the revised standard. This is considered to be indirect compliance.

Any exceedance of ALs must also be reported to the CNSC under REGDOC-3.1.1 [27]. The reporting process is described in BP-PROC-00165 [73]. According to BP-PROC-00171 [54], radiological emissions to the environment are kept ALARA by:

- Keeping radiological emissions below Internal Investigation Limits for each radionuclide group.
- Ensuring ALs are not exceeded.
- Ensuring that airborne and waterborne emissions are kept reasonably constant.
- Identify opportunities and taking action to reduce airborne and waterborne emissions during normal station operations.

The effectiveness of these measures is shown by the results described in Section 5.1.

It is concluded that Bruce Power meets the requirements of this review task.


## 5.6. On-Site Monitoring and Prompt Detection

The review task is to verify that:

On-site monitoring is undertaken at locations and using methods that have a high probability of the prompt detection of a release of radioactive material to the environment.

PROL Condition 9.1 requires that the licensee “implement and maintain an environmental program and undertake specific measures to control releases of nuclear and hazardous substances in accordance with applicable limits and to monitor effluents.” The control aspect of this condition implies the need for prompt detection of an unusually high release that could



 <div> <div>candesco</div> <div>Division of Kinectrics Inc.</div> </div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


result in the DRL being exceeded. CSA Standard N288.5-11 [32] includes guidance on process monitoring, which “is intended to allow operators to take timely action to ensure that effluent releases remain under control” (Section 0.2.2.3.2).

CNSC G-228 also requires that an AL be supported by a monitoring program that can accurately detect when the AL is reached. This program should consist of an appropriate methodology and frequency of sampling or measurement [24].

CSA Standard N288.7-15 describes the requirements for a groundwater protection program, including groundwater monitoring [45]. However, Clause 6.3.4 in the Standard states that, “The primary method for promptly detecting leaks from SSCs [structures, systems and components] should be from monitoring and surveillance activities performed within the facility. This includes systems to monitor and address buried and underground piping and tanks.” That is, groundwater monitoring should not be relied upon to provide prompt detection of a release of radioactive material into the environment.

Bruce Power’s Effluent Monitoring Program, BP-PROC-00080 [53], describes the requirements for on-site monitoring of effluents. It includes references to the requirements of N288.5-11, and Bruce Power has committed to be in full compliance with this standard by December 2018 [2], [70]. Among the objectives of the program are, “Confirm control at the source” and “Provide an indication of unusual conditions that might require corrective action.” The program is implemented by BP-PROC-00171 [54][35], which defines ALs at 10% of the release limits that could lead to a public dose limit being reached, and Internal Investigation Levels (IILs) at still lower values to “provide the earliest possible warning of abnormal system behavior and allow remedial action to be taken should a radionuclide emission show a steady upward trend over time” (Section 4.1). Actions to be taken when an IIL has been exceeded are prescribed in this document. ALs and IILs are defined for reporting periods of one week for airborne contaminants and of one month for waterborne contaminants. In addition, there are limits on the concentration of specific radionuclides in the condenser cooling water outfall and in unit stacks. Calculations of Maximum Probable Emission Rates (MPERs) are used to “determine whether there is a need to regularly monitor a potential emission source and the type of monitoring that may be required” (Section 4.13.1). Values of the calculated MPERs are documented in the Site Emission Monitoring Plan [74]. However, the report referenced in the Plan for the calculation of MPERs [75] has been superseded by a more recent report [76], and so the Plan should be updated. This discrepancy has been referred to Safety Factor 10: Organization and Administration as an example of a generic gap related to governance documents.

The Bruce Power Design Standard, Radionuclide Effluent Monitoring System Requirements, B-ST-03480-10000 [68], provides detailed guidance on the requirements for performance and control monitoring of airborne and waterborne effluent streams. In this document, “performance monitoring” is defined as “the monitoring of an emission source that potentially could emit an amount of radioactivity equivalent to a significant proportion of any Derived Release Limit. Performance monitoring is required to demonstrate compliance with regulatory limits, measure emissions performance, calculate the potential dose impact to a critical group” (Section 11.1.22). Control monitoring is defined as, “the monitoring of an emission source to provide adequate warning to ensure automatic or operator action can be taken so targets and regulatory limits are not exceeded” (Section 11.1.10). Control monitoring sampling frequencies for

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

continuous streams are specified to ensure that no more than 5% of the applicable weekly DRLs could be released without detection and alarm.

It is concluded that Bruce Power meets the requirements of this review task.

## 5.7. Off-Site Monitoring and Corrective Actions


The review task is to verify that:


Off-site monitoring for contamination levels and radiation levels is adequate and corrective actions are taken to keep such levels as low as reasonably achievable.

Off-site monitoring must be adequate to demonstrate compliance with public dose limits, DRLs and ALs, all of which are regulatory or licence requirements. In addition, Regulatory Guide G-129 [23] requires in Clause 7.3.3 that “radionuclide emissions to the environment are kept ALARA.” Detailed guidance for an EMP is provided in CSA Standard N288.4-10 [31].

Management of the off-site REMP is governed by BP-PROC-00076 [52]. The Bruce Power REMP states that it satisfies the requirements of CSA N288.4-10, although the company has not committed to full implementation of the standard until December 2018 [2], [70]. Data presented in the 2014 EMP Report [62] and reproduced in Figure 1 show that dose to the public due to releases from the station have remained low and quite constant since 2001. The dose in 2009 was somewhat elevated relative to other years due to tritium emission from the vacuum building and unit outages occurring at the same time as the annual produce sampling. This resulted in an overly conservative estimate of the public dose, and no corrective actions were considered to be required. As described in Section 5.1, public doses have been far below applicable limits and background levels leaving very limited opportunity for further reductions on the basis of ALARA.

It is concluded that Bruce Power meets the requirements of this review task.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00



**Figure 1: Historical Dose to Public Trend**

## 5.8. Contamination Levels


The review task is to verify that:

Actions have been taken to clean up contamination where reasonable and practicable.

Based on a search for reportable events in the Station Condition Record (SCR) database, no ALs related to environmental radiological releases have been exceeded in the last five years. Given that there have been no incidents where significant releases to the environment have occurred, this review task is interpreted to mean that actions have been taken to reduce radiological releases to the environment to levels that are below ALs and ALARA. One of these actions is to ensure that airstreams from contaminated areas are adequately cleaned of radioactive contamination before being released to the atmosphere. Effectiveness of the filters used for this is demonstrated by periodically testing their performance. A recent CSA Standard, N288.3.4-13 [44], establishes requirements and provides guidance for such testing.

If an AL is exceeded, Section 4.3.1 of BP-PROC-00171 [54] specifies the required actions, which include “Promptly identify source of emission (utilizing Task Analysis Meeting (TAM)) and mobilize prompt corrective action to reduce emissions to normal operating levels, including unit shut down if the source cannot be mitigated with the unit on-line.” Similar actions are required when an IIL is exceeded at more than 25% of an AL. Adoption of the ALARA principle is demonstrated by the actions listed in Section 5.5, above. Section 4.10 of BP-PROC-00171 also



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

requires that, to ensure the proper persons are notified and the appropriate level of response achieved when a spill or release is occurring, reference be made to BP-PROC-00059, Event Response and Reporting [77], and that initial sampling requirements be identified according to BP-PROC-00093, Spills to the Environment [78].

In addition, there is a Bruce Power procedure on the management of soil and groundwater contamination, BP-PROC-00241 [59]. While it applies to contamination on the Bruce Power site, appropriate management of such contamination should prevent its spread off-site. The procedure describes: evaluation of systems, structures and components or work practices that pose a risk for soil and groundwater contamination; conduct of environmental site assessments (including remediation and restoration); and operation of a routine groundwater monitoring program.

Regarding the performance testing of air-cleaning systems, BP-PROC-00171 [54] in Section 4.14.2.1 states that, "Performance Requirements for Contamination Exhaust Control Filters shall follow DPT-PE-00005, and should comply with CSA N288.3.4 Performance testing of nuclear air-cleaning systems at nuclear facilities." Testing of air-cleaning systems at the Bruce site is currently contracted to Kinectrics. The contract [79], in effect for 2012-2016, states that best practices shall be used. It further states, under Quality Assurance Requirements, "Work to be done in compliance to CSA N288.3.4." An assessment of N288.3.4-13 [44] revealed a number of gaps in the current Bruce Power program for filter performance testing, and these are described in detail in Appendix A (A.9). However, there is a corrective action plan in progress, described in AR 28506718, completion of which will bring Bruce Power into conformance with the standard by September 30, 2016.

It is concluded that Bruce Power meets the requirements of this review task.


## **5.9. Alarm Systems Responding to Unplanned Releases of Radioactive Material**

The review task is to verify that:

Alarm systems to respond to unplanned releases of radioactive material from on-site facilities are suitably designed and available and will remain available in the future.

PROL Condition 9.1 (see Section 3.2) requires the licensee to control and monitor releases of nuclear substances to the environment so that releases do not exceed DRLs. In CSA Standard N288.5-11 [32], Clause 0.2.2.3 describes process monitoring as a means "to allow operators to take timely action to ensure that effluent releases remain in control. As such, it generally requires the real-time (or near real-time) measurement of the instantaneous or short-term value of selected effluent parameters." There is no discussion in the standard of automatic alarms. The American National Standard ANSI/HPS N13.1-2011 [48] contains guidance on determining the level at which an alarm for airborne contamination should be generated (which it refers to as an "action level") and on determining whether a sampling or monitoring system is sufficiently sensitive to detect such a level.

Section 4.13 of BP-PROC-00171 [54] provides guidance on the calculation of MPEs, upon which monitoring requirements are based, and on actions to be taken when a stack monitor

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

alarm is exceeded. Appendix A of the site emission monitoring plan, NK29-PLAN-03480-00001 [74], shows stack alarms for high rates of release of noble gases, particulates and radioiodine. Table 1 of B-ST-03480-10000 [68] shows that alarms are required for monitoring airborne effluent streams, and a footnote states, “Alarms can be either physical devices or procedures which alert appropriate staff of monitor malfunction or emissions in excess of a set point or target. Justification for local or control room alarms and the type of alarm mechanism is at the discretion of the facility.” Section 4.14 of B-PROC-00171 [54] describes Quality Assurance/Quality Control (QA/QC) requirements, including specifications for instrument sensitivity and data uncertainty.

There is a Liquid Effluent Monitor in the discharge line to the condenser cooling water duct. According to the Bruce B 2012 Safety Report – Part 2 [80], Section 13.3.3, “A liquid effluent activity monitor is located in the discharge line. The monitor automatically causes the discharge flow to be shut off, and an annunciation in the main control room to be activated, if the activity level is too high. The wastes are then directed to the high activity collection tanks or the treatment facilities.” Table 2A of B-ST-03480-10000 [68] shows that alarms are required for liquid effluent batch streams from the Radioactive Liquid Waste Management System, and Table 2B provides the same information for liquid effluent batch streams from other systems. Table 3 of this standard specifies alarms for liquid effluent continuous streams. All three of these tables include the same footnote regarding alarms as quoted above for airborne emissions.

Radioactive solid wastes produced at Bruce B are not normally removed from the Bruce site. Instead, they are transferred to the Western Waste Management Facility, which is operated by Ontario Power Generation on the Bruce site, for long-term storage. Bruce Power has established a “likely clean” program for Zone 2 wastes that are anticipated to be free of radioactive contamination. These wastes are packaged and handled separately from other Zone 2 wastes [81]. After monitoring, these wastes are “cleared” for disposal as inactive waste. A portal radiation monitor at the main gate provides an indication of the presence of radioactive material in (or on) any vehicle leaving the site. This would be sufficient to identify any unplanned release of solid radioactive wastes from the site. There are also contamination monitors for people and their possessions leaving potentially contaminated areas, which would alarm and prevent the spread of contamination to the environment.


It is concluded that Bruce Power meets the requirements of this review task.

## 5.10. Publication of Environmental Data

The review task is to verify that:

Appropriate data have been published on the environmental impact of the plant.

PROL Condition G.5 (see Section 3.2) requires the licensee to implement and maintain a public information and disclosure program. According to the LCH [2], this must be done in accordance with CNSC regulatory document RD/GD-99.3 [25]. CNSC REGDOC-3.1.1 [27] is listed under PROL Condition 3.3 (see Section 3.2) and sets reporting requirements for nuclear power plants.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Bruce Power reports quarterly and annually according to the requirements of REGDOC 3.1.1. The quarterly reporting requirement is met by submitting to the CNSC Quarterly Operations Reports, which include a section on environmental monitoring. Specifically, data on airborne and waterborne radioactive emissions, and unplanned monitoring are included in these reports. Facility emissions effective dose for Bruce A and B is no longer reported in station Quarterly Operations Reports since implementation of REGDOC-3.1.1, but it continues to be reported for the Central Maintenance and Laundry Facility in the Central Maintenance and Laundry Facility Quarterly Technical Reports. The annual Environmental Monitoring Program Report contains more complete and detailed information on the results of effluent and environmental monitoring, including historical trends for comparison. It is also submitted to the CNSC, and is subsequently posted on the Bruce Power website for public access.

CNSC REGDOC-3.1.1 specifies the type and frequency of reporting to the CNSC. It requires quarterly reporting of defined performance indicators, including radiological releases to the environment, and also annual reporting of information on environmental protection. It also regulates the issuing of event reports to the CNSC. The reporting done by Bruce Power satisfies the requirements of REGDOC-3.1.1.

In addition, CNSC RD/GD-99.3 [25] requires Class I facility operators to establish and operate a program for public information, including “routine and non-routine releases of radiological and hazardous materials to the environment” (Section 2.3.2).

The objective of the Bruce Power Stakeholder Interaction Program, BP-PROG-09.02 [82], is “to ensure groups and individuals who have the potential to influence Bruce Power’s success are identified, their interests and requirements are understood and they receive the appropriate level of communication, according to a defined disclosure protocol.” The program is implemented, in part, by a procedure for responding to enquiries from the public, BP-PROC-00052 [83], and a procedure for disclosing information to stakeholders, BP-PROC-00919 [84].


These procedures aim to ensure open and transparent communication with the public, community, and stakeholders and organizations with an interest in Bruce Power’s operations. For instance, Bruce Power’s Website provides a user-friendly and accessible platform for members of the public to obtain information about Bruce Power’s values and policies, environmental assessments, including publishing:

- an annual assessment report on environmental and radiological data (<http://www.brucepower.com/category/reports/environmental-reports/>); and
- Licence Renewal activities (<http://www.brucepower.com/licence-renewal-2015/>).

The Website also offers other means for staying connected with the community, including social media, publishing:

- quarterly reports (<http://www.brucepower.com/community/community-updates/>), which are distributed to 50,000 people in Bruce, Grey and Huron Counties; and
- annual reports (<http://www.brucepower.com/reports-archive/>) available to all readers.

It is concluded that Bruce Power meets the requirements of this review task.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## 5.11. Changes in the Use of Areas Around the Site

The review task is to verify that:

Changes in the use of areas around the site have been taken into account in the development of monitoring programs.

Section 5.3.1 of CSA Standard N288.4-10 [31] lists a number of events that should initiate a review of the EMP. One of these is “a change in the population or land use in the surrounding community.”

Section 4.3 of DPT-ENV-00016 [57] presents a list of sources of information on changes that can result in a revision to the Environmental Aspects database, and potentially to the EMP. The Environmental Aspects database is a password protected spreadsheet that demonstrates how Environmental Aspects and Significant Environmental Aspects are managed at Bruce Power. One of the sources of information is “Changes in the surrounding community including new public interest or concerns.” In addition, BP-PROC-00076 [52] requires in Section 4.5.6.1 an annual review of the EMP, including an assessment of “Any site-specific parameters that have changed such as land usage, population distribution, meteorology, hydrology, water uses, food sources, etc.” There is also a requirement for a “systematic review of the REMP design” at least every five years, per Section 4.5.6.2 of BP-PROC-00076.


The site specific survey provides information regarding land usage, population distribution, water sources, water use and food sources in the vicinity of the Bruce Power site. The site specific survey is conducted every five years or prior to licence renewal unless a significant change in the community or site operations requires an earlier survey. The information from this survey is used to update potential critical groups, conduct pathways analysis and subsequently update the DRLs for the nuclear facilities on the Bruce Power site. These changes may also result in changes to the EMP. The most recent site specific survey was conducted in 2011 [85].

It is concluded that Bruce Power meets the requirements of this review task.

## 6. Interfaces with Other Safety Factors

There is some degree of interrelationship among most of the 15 Safety Factors that comprise the Bruce B PSR. The following identifies specific aspects of this Safety Factor that are addressed in, or where more detail is provided in, another Safety Factor Report.

- “Safety Factor 1: Plant Design” in Appendix B.2, assesses requirements and guidance regarding environmental protection considerations within the plant design.
- “Safety Factor 8: Safety Performance” in Section 4.6, discusses the Corrective Action Program which addresses issues identified through internal, independent audits of the EMS and REMP.
- “Safety Factor 10: Organization and Administration” in Section 5.4.8, discusses the prioritization of safety issues, with realistic objectives and timescales, that ensures that these issues receive proper resources.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- “Safety Factor 11: Procedures” in Appendix B.2, assesses requirements and guidance related to radioactive waste.

For the purposes of this assessment, the following scopes have been assumed for Safety Factors 13, 14 and 15:

- “Safety Factor 13: Emergency Planning” has been interpreted to include the preparations made for the protection of people and the environment from the adverse effects of exposure to ionizing radiation during abnormal operations;
- “Safety Factor 14 (this report): Radiological Impact on the Environment” has been interpreted to include the protection of people and the environment outside the Protected Area of the station from the adverse effects of exposure to ionizing radiation during normal operations which includes anticipated operational occurrences; and
- “Safety Factor 15: Radiation Protection” has been interpreted to include the protection of people inside the Protected Area of the station from the adverse effects of exposure to ionizing radiation during normal operations which includes anticipated operational occurrences (there are no natural areas of any significance inside the Protected Area of the station).

## 7. Program Assessments and Adequacy of Implementation

Section 7 supplements the assessments of the review tasks in Section 5, by providing information on four broad methods used to identify the effectiveness with which programs are implemented, as follows:


- Self-Assessments;
- Internal and External Audits and Reviews;
- Regulatory Evaluations; and
- Performance Indicators.

For the first three methods, the most pertinent self-assessments, audits and regulatory evaluations are assessed. Bruce Power has a comprehensive process of reviewing compliance with Bruce Power processes, identifying gaps, committing to corrective actions, and following up to confirm completion and effectiveness of these actions. While there have been instances of non-compliance with Bruce Power processes, Bruce Power’s commitment to continuous improvement is intended to correct any deficiencies.

For the fourth method, the performance indicators relevant to this Safety Factor are provided. These are intended to demonstrate that there is a metric by which Bruce Power assesses the effectiveness of the programs relevant to this Safety Factor.

Taken as a whole, these methods demonstrate that the processes associated with this Safety Factor are implemented effectively (individual findings notwithstanding). Thus, program



	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

effectiveness can be inferred if Bruce Power processes meet the Safety Factor requirements and if there are ongoing processes to ensure compliance with Bruce Power processes. This is the intent of Section 7.

## 7.1. Self-Assessments

Generally, self-assessments are used by functional areas to assess the adequacy and effective implementation of their programs. The results of each assessment are compared with business needs, the Bruce Power management system, industry standards of excellence and regulatory/statutory or other legal requirements. Where gaps are identified, corrective actions are identified and implemented.

The self-assessments:

- Identify internal strengths and best practices;
- Identify performance and/or programmatic gap(s) as compared to targets, governance standards and “best in class”;
- Identify gaps in knowledge/skills of staff;
- Identify the extent of adherence to established processes and whether the desired level quality is being achieved;
- Identify adverse conditions and Opportunities for Improvements (OFI); and
- Identify the specific improvement corrective actions to close the performance/programmatic gap.


Focus Area Self-Assessment SA-ENV-2011-01, Effluent Monitoring – Radiological, October 2011 [86]

This self-assessment reviewed Bruce Power’s Radiological Effluent Monitoring Program against CSA Standard N288.5 [32], with the objective of identifying actions required to ensure compliance. Many gaps and deficiencies were found, both in program documentation and in execution. These led to numerous action assignments, documented in Action Requests 28266485 and 28238120. All assignments have been completed by their due date, with some outstanding and the last ones due by June 15, 2017.

Focus Area Self-Assessment SA-ENV-2011-02, Effectiveness Review on Environmental Impact Worksheets (EIW), September 30, 2011 [87].

The objective of this self-assessment was to “Review the effectiveness of environmental impact worksheet and practices at Bruce Power in relation to top performers in the industry and provide areas for improvement.” Four issues were identified:

#1: “Some activities that interact with the environment occurred because the process of assessing impacts on the environment was not followed or form 11422 (EIW) was not used.”

 <div style="font-size: small;">Division of Kinectrics Inc.</div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

#2: "... EIWs are not clearly understood by project proponent, environmental officers in field and environmental programs."

#3: "There are instances where follow-up actions are not tracked for completion and EIW forms cannot be retrieved for oversight and assessment purpose."

#4: "There is no effective oversight on EIWs to make sure if all environmental and waste management consideration are taken care of and EIW are managed to their completion."


While all of the examples given in this self-assessment were related to non-radiological environmental impacts, the issues identified would also have a negative effect on the identification of radiological environmental impacts. All of the 24 corrective actions arising from this self-assessment had been completed by June 30, 2013 (AR 28266253).

Focus Area Self-Assessment SA-ENV-2012-01, Environmental Monitoring – N288.4-10, December 2012 [88].

This self-assessment was performed to review Bruce Power's EMP against the requirements of CSA Standard N288.4-10 and to identify actions for implementation to ensure compliance. Many adverse conditions were identified related to inadequacy of current documentation relative to that required by the standard. One adverse condition was the absence of an implementation plan for N288.4-10, and another was the need to review and document the effectiveness of implementation of the standard. There were also three opportunities for improvement noted, one of which was to implement the use of one software system for data management that minimized human intervention. The corrective action plan, documented under AR 28335084, contains 27 assignments, of which 24 were completed by their due dates and the remaining 3 are due by October 31, 2016. The assignment to prepare an implementation plan for N288.4-10 was closed as complete on December 12, 2013, with a note that it was done in Microsoft Project with multiple levels.

Focus Area Self-Assessment SA-ENV-2013-01, Transition to CSA N288.6 Environmental Risk Assessments at Class I Nuclear Facilities and Uranium Mines and Mills, December 1, 2013 [89].

The purpose of this self-assessment was to review Bruce Power processes, policies and procedures against the requirements of CSA Standard N288.6-12. It looked at the high-level implementation plan that had been submitted to CNSC as part of the PROL licence renewal application, and assessed progress on that plan. The self-assessment identified five issues; four of these related to interfaces between Bruce Power and other users of the Bruce site, and the CNSC. The one issue that is relevant to this Safety Factor was #5, which was that the Bruce Power Tier 2/Tier 3 risks had not yet been identified. The corrective action was to ensure that several of the steps in the Implementation Plan will be completed following the Tier 2/Tier 3 ERA, by adding additional activities to Action Tracking. This has been done under AR 28405618, and the actions due so far have been either cancelled or completed. Many actions remain open for completion by dates in 2016-2018.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Focus Area Self-Assessment SA-CHEM-2013-01, Chemistry Quality Assurance/Quality Control Management Standards, December 20, 2013 [69].

Station Chemistry Labs analyze effluent samples, and are therefore subject to the requirements of Standard CSA 288.5-11 [32]. The CSA Standard in turn requires analytical labs to establish and maintain QA/QC programs such as those described by the ISO/IEC Standard 17025 [66]. This self-assessment looked at compliance of the Chemistry Program and Labs with the requirements of ISO/IEC 17025. It found numerous program gaps, infrastructure deficiencies and compliance gaps. Several Action Requests resulted: 28410002, 28410004, 28410009, 28410013 and 28410030. Most of the assignments have been completed, several are not yet due, and the last one is due December 30, 2016.


Focus Area Self-Assessment SA-ENV-2014-01, N288.7 – Groundwater Protection Program, December 5, 2014 [90].

In anticipation of the publication of CSA Standard N288.7 in June 2015, this self-assessment conducted a clause-by-clause review of the draft standard as it stood at the end of 2014. Bruce Power staff were included in the Subcommittee formed to write the standard, and so the company was aware of the content of the draft document and knew that it was close to final. The objective of the self-assessment was to apply the requirements of the draft standard to the condition of one specific area on the Bruce site, the Bunker C Oil and Ignition Day Tank area, “in order to understand the deficiencies and thus make suggestions to close gaps that exist between the groundwater monitoring program as it exists today and what will be expected once the standard is published” (Section 4.0). It was acknowledged that there was no groundwater protection program in effect at Bruce Power, and that consequently there were going to be many gaps identified. The self-assessment resulted in 14 SCRs with a total of 52 assignments, completion of which would lead to the establishment of a groundwater protection program in compliance with N288.7-15. All assignments have a due date of June 15, 2016.

“Quick Hit” Self-Assessment SA-ENV-2015-02, ISO 14001:2015 New Standard Evaluation, November 20, 2015 [61].

A new revision of the standard ISO 14001 on environmental management systems was released on September 15, 2015, superseding the previous revision of 2004. This self-assessment was conducted under contract to Bruce Power to “look at the EMS program and identify gaps with the new standard across the company and outline actions required to meet the intent of the new standard” (Section 3.0). Compliance with the new version of the standard is required by September 14, 2018, in order to maintain Bruce Power’s Certificate of Registration with ISO 14001. An audit against the new standard is expected in the fall of 2017, so the goal is for Bruce Power to meet the intent of it by that time. The self-assessment identified many gaps, and these led to opportunities for improvement, documented in SCR 28530029. There are 21 assignments, with due dates from January 30, 2015, to March 15, 2018.



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## 7.2. Internal and External Audits and Reviews

The objective of the audit process as stated in BP-PROG-15.01 [91] is threefold:


- To assess the Management System and to determine if it is adequately established, implemented, and controlled;
- To confirm the effectiveness of the Management System in achieving the expected results and that risks are identified and managed; and
- To identify substandard conditions and enhancement opportunities.

The objective is achieved by providing a prescribed method for evaluating established requirements against plant documentation, field conditions and work practices. The process describes the activities associated with audit planning, conducting, reporting, and closing-out. The results of the independent assessments are documented and reported to the level of management having sufficient breadth of responsibility for resolving any identified problems (as stated in Section 5.14.2 of [28]).

### 7.2.1. Internal Audits

Nine audits performed by the Bruce Power Nuclear Oversight and Regulatory Affairs Division were reviewed. The bases for these audits were S-296 [35], ISO 14001:2004 [51], CSA N288.4-10 [31] and any applicable legal and internal requirements. The focus areas of each audit were as indicated below.

- Audit Report AU-2010-00005, EMS and Environment Compliance Audit, June 2010 [92].  
Focus was on air emissions, ozone depleting substances and spills management.
- Audit Report AU-2010-00035, Radiation Environmental Monitoring Program (REMP), October 2010 [93].  
Focus was on compliance with core element requirements defined in the following clauses of N288.4-10 [31]:
  - Clause 6 – Design of an EMP
  - Clause 8 – Sampling and analytical procedures
  - Clause 9 – Interpretation of data
  - Clause 10 – Quality assurance (QA) and quality control (QC)
  - Clause 11 – Reporting, review and audit.
- Audit Report AU-2011-00002, EMS & Environmental Compliance, June 2011 [94]  
Focus was on water emissions, chemical storage and handling, and conventional impacts and biodiversity management.
- Audit Report AU-2012-00003, Environmental Safety Management, May 2012 [95].  
Focus was on air emissions, waste management, PCBs and “other” requirements.
- Audit Report AU-2012-00004, Radiation Environmental Monitoring (REMP) Audit, December 2012 [96].

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


Focus was on compliance with non-core element requirements defined in the following clauses of N288.4-10 [31]:

- Clause 4 - Objectives of an EMP
  - Clause 5 - Criteria for establishing and revising an EMP
  - Clause 7 - Guidance for design elements of an EMP
  - Clause 12 - Staff qualifications and training
  - Clause 13 - Documentation.
- Audit Report AU-2013-00003, Environmental Safety Management Audit, June 2013 [97].  
Focus was on conventional and radioactive water emissions, ozone depleting substances and spills management.
  - Audit Report AU-2014-00003, Environmental Safety Management, May 2014 [98].  
Focus was on conventional and radioactive air emissions, chemical storage and handling and impacts management.
  - Audit Report AU-2014-00004, Radiation Environmental Monitoring – Essential Elements, August 2014 [67].  
Focus was on the same core element requirements as in the audit reported in AU-2010-00035, and so the results of this audit supersede those of the earlier audit.
  - Audit Report AU-2015-00001, Environmental Safety Management, July 2015 [99]  
Focus was on conventional and radioactive water emissions, waste management, PCBs management and other requirements.

In general, all nine audits found that the Bruce Power EMS meets the requirements of ISO 14001:2004 and in the vast majority of cases is compliant with regulatory requirements. However, weaknesses were noted in several areas; the more recent audits have identified the following general adverse conditions:

- Poor corrective action completion and effectiveness, including corrective actions arising from previous audits – this was a repeat finding common to all audits;
- FASA SCRs not adhering to relevant procedure;
- Documentation not always maintained as required;
- Record creation and retention not always performed as required;
- Capability profiles of environmental staff not maintained and work sometimes performed by unqualified persons;
- Register for identifying legal requirements not always current and accurate;
- Environmental impacts of operational changes not effectively controlled.

These weaknesses relate to quality management issues, rather than technical deficiencies. Consequently, they are not directly related to the review tasks of this Safety Factor.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

The May 2014 audit, AU-2014-00003 [98], found that some Bruce B stacks that require performance monitoring, based on calculated MPEs, did not have monitors installed. This raised a “risk that a lack of monitoring on these emissions pathways could be interpreted to be a non-compliance with the CNSC requirements” (Section 4.1.1). SCR 28447907 was initiated to document the adverse condition and its corrective action plan. There are 21 assignments, of which 16 are complete, 3 are due for completion by November 2016, and 2 are due for completion in January 2017.

The August 2014 audit, AU-2014-00004 [67], found that some technical requirements of the REMP were not always met. Specifically:

- Sampling specifications and instructions were not adequate; and
- There was noncompliance with reporting of sample results and associated uncertainties.

These technical findings could have a negative impact on the reliability and credibility of the REMP results. Bruce Power management has accepted the findings, and 12 corrective actions were complete by June 30, 2015 (AR 28456570). Two additional assignments, due October 31, 2016, have been added to review all of the document changes required by the previous assignments and closed to Document Change Requests.

The August 2014 audit report also noted that there has been progress towards implementation of the requirements of CSA Standard N288.4-10 in anticipation of it becoming a licence requirement, but the REMP was not yet fully compliant with it.

The July 2015 audit report, AU-2015-00001 [99], noted that there had been inadequate implementation of IILs, ALs and DRLs for waterborne radioactive effluent in the emissions monitoring program, and that IIL exceedances were not always identified and reported in SCRs. There were also inconsistencies and omissions in the radionuclide libraries used by the chemistry labs compared with the requirements of the emissions monitoring program. The report noted non-adherence to Bruce Power’s analytical capability requirements and to active liquid waste sample collection requirements. Gaps were found in reporting of radiological water emissions. The adverse conditions were documented in three SCRs: 28503484, 28525204 and 28525288, and a total of 13 assignments was created. Three of these are complete and the rest are due for completion by the end of 2016.


## 7.2.2. External Audits and Reviews

CALA performed assessments of the Health Physics Laboratory in 2012 [100], 2014 [101] and 2015 [102] to verify compliance with ISO/IEC 17025 [66], for purposes of accrediting the laboratory to that standard.

In the 2012 assessment, CALA identified four non-conformances, all related to quality assurance and documentation (AR 28315267). The necessary changes to documents have been made.

In the 2014 assessment, there were eight findings (AR 28450986). Most again were related to quality assurance and documentation, but two had technical implications:

- “No documentation for [sample] holding times was defined”.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- “Verify that all reagents are labelled with material concentration or purity, date of prep and expiry date.”

The corrective action for the first of these has been completed. No corrective action was defined for the second finding, possibly because it was rated “Type C”, meaning an optional recommendation.

In the 2015 assessment, there was one Type A (required) action, which was to include a unique identification of the test report or certificate on each page, and a clear identification of the end of the report or certificate. The action was completed by the due date of September 26, 2015. There were also two Type B (recommended) actions to make minor revisions to a laboratory procedure; both of these actions were captured in a DCR.

### 7.3. Regulatory Evaluations and Reviews

After a licence is issued, the CNSC stringently evaluates compliance by the licensee on a regular basis. In addition to having a team of onsite inspectors, CNSC staff with specific technical expertise regularly visit plants to verify that licensees are meeting the regulatory requirements and licence conditions. Compliance activities include inspections and other oversight functions that verify a licensee’s activities are properly conducted, including planned Type I inspections (detailed audits), Type II inspections (routine inspections), assessments of information submitted by the licensee to demonstrate compliance, and other unplanned inspections in response to special circumstances or events.


Type I inspections are systematic, planned and documented processes to determine whether a licensee program, process or practice complies with regulatory requirements. Type II inspections are planned and documented activities to verify the results of licensee processes and not the processes themselves. They are typically routine inspections of specified equipment, facility material systems or of discrete records, products or outputs from licensee processes.

The CNSC carefully reviews any items of non-compliance and follows up to ensure all items are quickly corrected.

Following is a list of CNSC inspection reports related to this Safety Factor, with a summary of their conclusions.

- Bruce A and B Radiological Environmental Monitoring Program Inspection Report BRPD-2010-AB-010 [103].  
This CNSC inspection resulted in a single recommendation: that the Bruce Power Laboratory present data as collected (average/single point) and that the numbers be presented as such in the annual report as accurately as possible. Bruce Power responded by making the necessary document changes to implement the recommendation [104].
- Bruce A and Outside Bruce Power CNSC Compliance Inspection Report BRPD-A-2012-013 Environmental Monitoring Bruce A and Outside Bruce Power – Action Item 1207-3231 [105]

The general conclusion of this inspection report was that “the effluence and environmental monitoring program at the Bruce Power site meets the CNSC requirements. However, one

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

action notice has been raised as a result of this inspection.” That Action Item was to actively review a number of Temporary Configuration Changes that had been in place longer than permitted by Bruce Power procedure. Bruce Power notified the CNSC of their compliance with the Action Item in November 2012 [106], and the CNSC closed the Action Item in December 2012 [107].

- Bruce B CNSC Compliance Inspection Report BRPD-B-2012-022 – Effluent Monitoring Report [108].

The findings of this inspection were:

- Bruce Power staff followed appropriate program procedures for sampling and the plant configuration was in the expected state.
- Bruce Power is in compliance with the program procedures, and the regulatory requirements. There is an opportunity for improvement in the documentation surrounding extending the life of laboratory chemicals.
- Bruce Power is meeting the above stated requirement compliance with S-99 (superseded by REGDOC-3.1.1 [27]) by monitoring and recording releases of nuclear substances.
- Bruce Power is in compliance with regulatory requirements when identifying, recording and investigating adverse conditions.

There were no enforcement actions and only one minor recommendation was noted, that Bruce Power consider a documented process for extending the expiry dates of chemicals used in the lab. Implementation of such a recommendation is not required and is not tracked.


- Bruce A and B Quarterly Field Inspection Reports for Q4 of 2013-14 [109], Q1 of 2014-15 [110], Q2 of 2014-15 [111], Q3 of 2014-15 [112], Q4 of 2014-15 [113], and Q1 of 2015-16 [114].

Each of these routine inspection reports includes a section called “Effluent and Emissions Control – Monitoring Equipment”. The finding in each of these reports was that, “Bruce Power emissions were low and well below regulatory limits. Environmental monitoring equipment was observed to have no indications of impairments to functionality.” There were no enforcement actions resulting from these inspections.

- CNSC Type II Compliance Inspection Report: BRPD-AB-2014-013, Environmental Monitoring at Bruce Site [115].

The findings of this inspection were:

- Bruce Power is meeting the requirement to control procedures and maintenance of records including changes and revisions in accordance with CSA Standards N286-05 and S-296 / ISO 14001.”
- Equipment at the sampling sites was operational, and maintained and calibrated in accordance with a maintenance program.”
- Documented sampling procedures were consistently followed during sample collection.”

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- Bruce Power is meeting license requirements and industry standards with respect to Lab practices. Procedures, equipment calibration, training and QA/QC requirements.”
- Bruce Power was able to demonstrate clear traceability for radiological monitoring data retrieval and dose to public calculation process.

There were no enforcement actions arising from this inspection, but there were three minor recommendations from CNSC staff to Bruce Power:

- “... implement control measures to ensure large trees growing adjacent to the B7 sampling station do not pose a hazard to the sampling site”;
- “... use a different sampling device which will ensure no surface water debris is collected as part of the surface water samples”; and
- “... use new bottles for each sample collection to ensure no cross contamination occurs.

Implementation of such recommendations is not required and is not tracked.”

#### 7.4. Performance Indicators


Performance indicators are defined as data that are sensitive to and/or signals changes in the performance of systems, components, or programs.


The Bruce Power EPI is a composite report card which uses environmental events and regulatory infractions as a means to monitor and measure environmental performance [54]. The following environmental performance indicators are reported in the EPI:

- Spills and releases
- Regulatory infractions
- Water emissions
- Air emissions

Recent monthly values of the EPI are shown in Figure 2, taken from the Advanced Information Package prepared by Bruce Power for the Bruce B Operational Safety Review Team (OSART) Mission of December, 2015 [116]. The figure shows EPI values that are consistently above 90%, representing safe environmental performance.



 <div>Division of Kinectrics Inc.</div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00



**Figure 2: Environmental Performance Index**


In compliance with CNSC REGDOC-3.1.1, Bruce Power submits an annual report on environmental protection. The report for 2014 [61] gives the maximum dose to a representative person (“BMF3 Infant”) as 2.0  $\mu\text{Sv/y}$ , which is 0.2% of the applicable legal limit of 1 mSv/y. Quarterly reports on safety performance indicators include data on weekly airborne and monthly waterborne radiological emissions; the latest revision of the procedure for these reports [117] was issued to ensure compliance with CNSC REGDOC-3.1.1.

In addition, the CNSC produces an annual report on the safety performance of Canada’s NPPs. The report for 2014, Regulatory Oversight Report for Canadian Nuclear Power Plants: 2014 [118], summarizes the 2014 ratings for Canada’s NPPs in each of the 14 CNSC Safety and Control Areas (SCAs), including environmental protection. For 2014, the Bruce B rating for the environmental protection SCA was “satisfactory”, which indicates that the safety and control measures are effective. The same rating was received in the three preceding years.

## 8. Summary and Conclusions

The overall objectives of the Bruce B PSR are to conduct a review of Bruce B against modern codes and standards and international safety expectations, and to provide input to a practicable set of improvements to be conducted during the MCR in Units 5 to 8, as well as U0B, and during asset management activities to support ongoing operation of all four units, that will enhance safety to support long term operation. The specific objective of the review of this Safety Factor is to determine whether the operating organization has an adequate program for surveillance of the radiological impact of the plant on the environment, which ensures that emissions are properly controlled and are ALARA. This specific objective has been met by the completion of the review tasks specific to radiological impact on the environment.


Bruce Power’s Environmental Safety Management Program [50] and its procedures meet the requirements set out in the applicable regulations, Licence Conditions and regulatory

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

documents. The program is consistent with the current best practices in the industry and work is underway towards implementation of the latest industry standards: CSA N 288.4-10 [31], CSA N288.5-11 [32] and CSA N288.6-12 [33].


The overall conclusion is that Bruce Power meets the requirements of the Safety Factor related to the radiological impact of the plant on the environment.




	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## 9. References


- [1] NK21-CORR-00531-12136/NK29-CORR-00531-12546/E-DOC 4723908 , Nuclear Power Reactor Operating Licence, Bruce Nuclear Generating Stations A and B, PROL 18.00/2020, Canadian Nuclear Safety Commission, May 27, 2015.
- [2] NK21-CORR-00531-12135/NK29-CORR-00531-12545/E-DOC 4659316, Licence Conditions Handbook, LCH-BNGS-R000, Bruce Nuclear Generating Station A and Bruce Nuclear Generating Station B Nuclear Reactor Operating Licence, PROL 18.00/2020 (Effective: June 1, 2015), Canadian Nuclear Safety Commission, May 27, 2015.
- [3] CNSC REGDOC-2.3.3, Operating Performance: Periodic Safety Reviews, CNSC, April 2015.
- [4] BP-PROC-01024-R000, Periodic Safety Reviews, November 7, 2015.
- [5] NK29-CORR-00531-12932, Bruce B Periodic Safety Review Basis Document, Bruce Power Letter, F. Saunders to K. Lafrenière, January 25, 2016.
- [6] NK21-CORR-00531-11005/NK29-CORR-00531-11397, Submission of Safety Basis Report, Bruce Power Letter, F. Saunders to R. Lojk, December 30, 2013.
- [7] NK21-CORR-00531-00514, Bruce A: CNSC Approval to Restart Units 3 and 4 and Application to Amend PROL 15.01/2003, Bruce Power Letter, F. Saunders to J.H.M. Douglas, November 16, 2001.
- [8] NK21-CORR-00531-04636, Bruce A Units 1 and 2 Return to Service: Systematic Review of Safety – Basis, Bruce Power Letter, F. Saunders to D.A. Desjardins, December 22, 2006.
- [9] NK21-CORR-00531-04059, Bruce A Refurbishment for Life Extension – Systematic Review of Safety: Plant Design, Bruce Power Letter, F. Saunders to P. Webster, March 30, 2006.
- [10] NK21-CORR-00531-04339, Bruce A Units 1 and 2 Return to Service – Systematic Review of Safety, Bruce Power Letter, F. Saunders to P. Webster, July 31, 2006.
- [11] NK21-CORR-00531-05749, Bruce A Refurbishment for Life Extension and Continued Operation of Units 3 and 4 – Integrated Safety Review Basis, Bruce Power Letter, F. Saunders to P. Elder, February 29, 2008.
- [12] NK21-CORR-00531-05976, Bruce A Units 3 and 4 Refurbishment for Life Extension and Continued Operations: ISR Safety Factor Reports, Bruce Power Letter, F. Saunders to P. Elder, June 2, 2008.
- [13] NK21-CORR-00531-06596, Bruce A Units 3 and 4 Refurbishment for Life Extension and Continued Operation: ISR Safety Factor Reports 1, 2, 3 and 4, Bruce Power Letter, F. Saunders to K. Lafrenière, December 18, 2008.
- [14] NK21-CORR-00531-06076, Bruce A Units 3 and 4 Refurbishment for Life Extension and Continued Operation: ISR Safety Factor Reports 5, 6, and 7, Bruce Power Letter, F. Saunders to P. Elder, July 22, 2008.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00


- [15] NK21-REP-03600-00025 R001, Bruce NGS A Units 3 and 4 Global Assessment Report and Integrated Implementation Plan, May 29, 2009.
- [16] NK21-CORR-00531-11617, Integrated Safety Review for Bruce A, Bruce Power Letter, F. Saunders to K. Lafrenière, including enclosure K-421231-00010-R00, Candesco Report, October 27, 2014.
- [17] NK21-CORR-00531-12269, Bruce A Integrated Safety Review – Safety Factor Reports, Bruce Power Letter, F. Saunders to K. Lafrenière, August 27, 2015.
- [18] NK21-CORR-00531-10576/NK29-CORR-00531-10975, Application Requirements for Renewal of Power Reactor Operating Licences for Bruce Nuclear Generating Stations A and B, Bruce Power Letter, F. Saunders to R. Lojk, July 17, 2013.
- [19] NK29-CORR-00531-11252, Application for the Renewal of the Power Reactor Operating Licence for Bruce Nuclear Generating Station B, Bruce Power Letter, F. Saunders to M. Leblanc, October 31, 2013.
- [20] NK21-CORR-00531-11711/NK29-CORR-00531-12101, Bruce A and Bruce B Licence Renewal – Supplemental Update, Bruce Power Letter, F. Saunders to M. Leblanc, November 27, 2014.
- [21] NK21-CORR-00531-11715/NK29-CORR-00531-12105, Bruce Power: Requests and Supplemental Information for Licence Renewal, Bruce Power Letter, F. Saunders to M. Leblanc, November 28, 2014.
- [22] Nuclear Safety and Control Act, 1997, c. 9, N-28.3, Assented to March 20, 1997.
- [23] CNSC G-129 R001, Keeping Radiation Exposures and Doses “As Low As Reasonably Achievable (ALARA)”, CNSC Regulatory Guide, October 2004.
- [24] CNSC G-228, Developing and Using Action Levels, CNSC Regulatory Guide, March 2001.
- [25] CNSC RD/GD-99.3, Public Information and Disclosure, CNSC Regulatory Document, March 2012.
- [26] CNSC REGDOC-2.9.1, Environmental Protection: Policies, Programs and Procedures, CNSC Regulatory Document, September 2013.
- [27] CNSC REGDOC-3.1.1, Reporting Requirements for Nuclear Power Plants, CNSC Regulatory Document, May 2014.
- [28] CAN/CSA N286-05, Management System Requirements for Nuclear Power Plants, CSA, February 2005, (Update No.2, 2010), R2010.
- [29] CSA N286-12, Management system requirements for nuclear facilities, CSA Standard, June 2012.
- [30] CSA N288.1-14, Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities, CSA Standard, March 2014.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [31] CSA N288.4-10, Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills, CSA Standard, May 2010.
- [32] CSA N288.5-11, Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills, CSA Standard, April 2011.
- [33] CSA N288.6-12, Environmental risk assessments at Class I nuclear facilities and uranium mines and mills, CSA Standard, June 2012.
- [34] CSA N292.3-14, Management of low- and intermediate-level radioactive waste, CSA Standard, May 2014.
- [35] CNSC S-296, Environmental Protection Policies, Programs and Procedures at Class I Nuclear Facilities and Uranium Mines and Mills, CNSC Regulatory Standard, March 2006.
- [36] CNSC G-296, Developing Environmental Protection Policies, Programs and Procedures at Class I Nuclear Facilities and Uranium Mines and Mills, CNSC Regulatory Guide, March 2006.
- [37] NK21-CORR-00531-11494/NK29-CORR-00531-11881, Response to Bruce Power letter, CSA N286-12 "Management system requirements for nuclear facilities", Action Item 1307-4697, CNSC Letter, K. Lafrenière to F. Saunders, July 24, 2014.
- [38] NK21-CORR-00531-11189/NK29-CORR-00531-11593, Action Item 1307-4697: CSA N286-12 Management System Requirements for Nuclear Facilities, Bruce Power Letter, F. Saunders to K. Lafrenière, May 16, 2014.
- [39] NK21-CORR-00531-11563/NK29-CORR-00531-11946, CSA N286-12 - Management System Requirements for Nuclear Facilities, Action Item 1307-4697, Bruce Power Letter, F. Saunders to K. Lafrenière, September 9, 2014.
- [40] NK21-CORR-00531-12570/NK29-CORR-00531-12996, Action Item 1307-4697: CSA N286-12 - Management Systems Requirements for Nuclear Facilities, Bruce Power Letter, F. Saunders to K. Lafrenière, January 29, 2016.
- [41] CNSC RD-346, Site Evaluation for New Nuclear Power Plants, CNSC Regulatory Document, November 2008.
- [42] IAEA NS-R-3, Site Evaluation for Nuclear Installations, IAEA, November 2003.
- [43] NK29-REP-07730-00001-R001, New Fuel Project for Bruce B: Environmental Assessment Study Report, October 22, 2004.
- [44] CSA N288.3.4-13, Performance Testing of Nuclear Air-Cleaning Systems at Nuclear Facilities, CSA Standard, March 2013.
- [45] CSA N288.7-15, Groundwater Protection programs at Class I nuclear facilities and uranium mines and mills, CSA Standard, June 2015.
- [46] IAEA NS-G-3.2, Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants, IAEA Safety Guide, March 2002.


 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [47] IAEA SSG-25, Periodic Safety Review of Nuclear Power Plants, IAEA Specific Safety Guide, March 2013.
- [48] ANSI/HPS N13.1-1999 (R2011), Sampling and Monitoring Releases of Airborne Radioactive Substances From the Stacks and Ducts of Nuclear Facilities, Health Physics Society/American National Standard, March 30, 2011.
- [49] BP-MSM-1-R012, Management System Manual, Bruce Power, June 23, 2014.
- [50] BP-PROG-00.02-R009, Environmental Safety Management, Bruce Power, October 22, 2014.
- [51] ISO 14001:2004, Environmental Management System – Requirements with Guidance for Use, International Organization for Standardization, ISO, 2004.
- [52] BP-PROC-00076-R006, Management of the Off-Site Radiological Environmental Monitoring Program, Bruce Power, March 4, 2015.
- [53] BP-PROC-00080-R006, Effluent Monitoring Program, Bruce Power, October 23, 2013.
- [54] BP-PROC-00171-R018, Radiological Emissions Monitoring: Limits, Action Levels, Bruce Power, November 21, 2014.
- [55] NK29-REP-03482-00003-R002, Derived Release Limits and Action Levels for Bruce Nuclear Generating Station B, Bruce Power, October 2013.
- [56] BP-PROC-00793-R002, Environmental Performance Index Indicators and Reporting Procedure, Bruce Power Procedure, January 12, 2015.
- [57] DPT-ENV-00016-R006, Environmental Risk Assessment – Aspect/Impact, Bruce Power, June 22, 2015.
- [58] BP-PROC-00870-R002, Spill Management and Contaminated Lands Program, Bruce Power Procedure, July 14, 2014.
- [59] BP-PROC-00241-R003, Management of Soil and Groundwater Contamination, Bruce Power, June 23, 2015.
- [60] ISO 14001:2015, Environmental Management System – Requirements with Guidance for Use, Third Edition, International Organization for Standardization, 2015.
- [61] SA-ENV-2015-02, “Quick Hit” Self-Assessment, ISO 14001:2015 New Standard Evaluation, Bruce Power FASA, November 20, 2015.
- [62] B-REP-07000-00007-R000, 2014 Environmental Monitoring Program Report, Bruce Power, April 2015.
- [63] B-REP-03443-00011-R000, Screening Level Environmental Risk Assessment for Bruce Nuclear Facility, March 2013.
- [64] B-REP-03443-00012-R000, Bruce Power/CNL Douglas Point Environmental Quantitative Risk Assessment, January 2015.
- [65] B-CALC-32310-00001-R000, Tritium Gas Emissions from Bruce Nuclear Generating Stations, October 8, 2013.


	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [66] ISO/IEC 17025, General Requirements for the Competence of Testing and Calibration Laboratories, International Organization for Standardization, May 15, 2005.
- [67] AU-2014-00004, Radiation Environmental Monitoring – Essential Elements, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved September 17, 2014.
- [68] B-ST-03480-10000-R001, Radionuclide Effluent Monitoring System Requirements, Bruce Power, February 17, 2005.
- [69] SA-CHEM-2013-01, Chemistry Quality Assurance/Quality Control Management Standards, Focus Area Self-Assessment, Bruce Power, December 20, 2013.
- [70] NK29-CORR-00531-11379, Bruce A and B – Response to Notification of Completeness of Licence Renewal Applications, Bruce Power Letter, F Saunders to R. Lojk, February 4, 2014.
- [71] CSA N288.1-08 (Update No. 1), Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities, CSA Standard, May 2011.
- [72] CANDU Owners Group, R&D Work Package #30495 for Program Year 2014/2015, R001, September 15, 2014.
- [73] BP-PROC-00165-R012, Reporting to CNSC – Power Reactor Operating Licences, Bruce Power, December 22, 2014.
- [74] NK29-PLAN-03480-00001-R001, Site Emission Monitoring Plan – Bruce B, Bruce Power, March 18, 2010.
- [75] B-REP-03480-00002-R002, Derivation of Maximum Probable Emission Rates for Bruce NGS A and Bruce NGS B, Bruce Power Report, October 28, 2004.
- [76] B-REP-03480-00005-R001, Maximum Probable Emission Rate Calculations for Bruce A, Bruce B, and CMLF, Bruce Power Report, May 2013.
- [77] BP-PROC-00059-R022, Event Response and Reporting, Bruce Power, December 11, 2014.
- [78] BP-PROC-00093-R016, Spills to the Environment, Bruce Power, July 3, 2014.
- [79] Bruce Power Contract 00171851, 2012-2016 Testing of Air Cleaning Systems at Site by Kinectrics, March 2, 2012. With Appendix A: Bruce Power Stack Filter Testing: Stack Recovery, Stack Flow, Stack Monitor and Stack Filter Characterization Services Scope of Work, December 15, 2011.
- [80] NK29-SR-01320-00001-R005, Bruce B 2012 Safety Report – Part 2: Plant Components and Systems, Bruce Power, January 2013.
- [81] BP-RPP-00010-R005, Segregation and Handling of Radioactive Waste, Bruce Power, April 5, 2013.
- [82] BP-PROG-09.02-R005, Stakeholder Interaction, Bruce Power, June 18, 2014.




 <div>Division of Kinectrics Inc.</div>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [83] BP-PROC-00052-R006, Public Inquiry and Response, Bruce Power, July 15, 2014.
- [84] BP-PROC-00919-R000, Stakeholder Information Disclosure, Bruce Power, August 13, 2013.
- [85] B-REP-03443-00009-R001, 2011 Site Specific Survey Report for the Bruce Power Site, Bruce Power, January 2013.
- [86] SA-ENV-2011-01, Focus Area Self-Assessment, Effluent Monitoring - Radiological, Bruce Power, September 30, 2011.
- [87] SA-ENV-2011-02, Focus Area Self-Assessment, Effectiveness Review on Environmental Impact Worksheets (EIW), Bruce Power, September 30, 2011.
- [88] SA-ENV-2012-01, Focus Area Self-Assessment, Environmental Monitoring – N288.4-10, Bruce Power, December 2012.
- [89] SA-ENV-2013-01 (A/R 28337068-01), Transition to CSA N288.6 Environmental Risk Assessments at Class I Nuclear Facilities and Uranium Mines and Mills, Bruce Power Focus Area Self-Assessment, December 1, 2013.
- [90] SA-ENV-2014-01, Focus Area Self-Assessment, N288.7 – Groundwater Protection Program, Bruce Power, December 5, 2014.
- [91] BP-PROG-15.01-R004, Nuclear Oversight Management, Bruce Power, December 18, 2013.
- [92] AU-2010-00005, EMS and Environment Compliance Audit, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved September 14, 2010.
- [93] AU-2010-00035, Radiation Environmental Monitoring Program (REMP), Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved November 18, 2010.
- [94] AU-2011-00002, EMS & Environmental Compliance, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved August 11, 2011.
- [95] AU-2012-00003, Environmental Safety Management, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved August 2, 2012.
- [96] AU-2012-00004, Radiation Environmental Monitoring, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved February 11, 2013.
- [97] AU-2013-00003, Environmental Safety Management Audit, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved August 8, 2013.
- [98] AU-2014-00003, Audit Report: Environmental Safety Management, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved July 29, 2014.
- [99] AU-2015-00001, Environmental Safety Management, Nuclear Oversight and Regulatory Affairs Division, Bruce Power Audit Report, Approved November 26, 2015.
- [100] Action Request 28315267, CALA Audit Report of the BP Health Physics Laboratory, Bruce Power, Event Date August 16, 2012.


 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [101] Action Request 28450986, Dosimetry Lab CALA Audit, Bruce Power, Event Date August 14, 2014.
- [102] 2015 CALA Assessment 3203-2560, Bruce Power Health Physics Laboratory - CALA Accreditation Program, August 17, 2015.
- [103] NK29-CORR-00531-09113, Bruce A and B Radiological Environmental Monitoring Program Inspection Report BRPD-2010-AB-010, CNSC Letter, K. Lafrenière to F. Saunders, November 16, 2010.
- [104] NK29-CORR-00531-09378, Bruce A and B Radiological Environmental Monitoring Program Inspection Report BRPD-2010-AB-010, Bruce Power Letter, F. Saunders to K. Lafrenière, April 27, 2011.
- [105] NK21-CORR-00531-09425, Bruce A and Outside Bruce Power CNSC Compliance Inspection Report BRPD-A-2012-013 Environmental Monitoring Bruce A and Outside Bruce Power – Action Item 1207-3231, CNSC Letter, R. Lojk to F. Saunders, April 11, 2012.
- [106] NK21-CORR-00531-10036, Action Item 1207-3231: Temporary Configuration Change (TCC), Bruce Power Letter, F. Saunders to R. Lojk, November 28, 2012.
- [107] NK21-CORR-00531-10138, Closure of Action Item 1207-3231: Temporary Configuration Change (TCC), CNSC Letter, R. Lojk to F. Saunders, December 28, 2012.
- [108] NK29-CORR-00531-10526, Bruce B CNSC Compliance Inspection Report BRPD-B-2012-022 – Effluent Monitoring Report, CNSC Letter, R. Lojk to F. Saunders, December 20, 2012.
- [109] NK29-CORR-00531-11755, Bruce A and B Quarterly Field Inspection Report for Q4 of 2013-14 (BRPD-AB-2014-003), CNSC Letter, K. Lafrenière to F. Saunders, May 21, 2014.
- [110] NK29-CORR-00531-11932, Bruce A and B Quarterly Field Inspection Report for Q1 of 2014-15 BRPD-AB-2014-008, CNSC Letter, K. Lafrenière to F. Saunders, August 20, 2014.
- [111] NK29-CORR-00531-12088, Bruce A and B Quarterly Field Inspection Report for Q2 of 2014-15 BRPD-AB-2014-011, CNSC Letter, K. Lafrenière to F. Saunders, November 4, 2014.
- [112] NK29-CORR-00531-12283, Action Item 2015-07-5155: CNSC Type II Compliance Inspection Report: BRPD-AB-2014-020, Bruce A and B Generating Stations Quarterly Field Inspection Report for Q3 2014-15, CNSC Letter, K. Lafrenière to F. Saunders, January 28, 2015.
- [113] NK29-CORR-00531-12565, CNSC Type II Compliance Inspection Report: BRPD-AB-2015-003, Bruce A and B Generating Stations Quarterly Field Inspection Report for Q4 2014-15, CNSC Letter, K. Lafrenière to F. Saunders, June 5, 2015.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

- [114] NK29-CORR-00531-12715, Action Item 2015-07-5489: CNSC Type II Compliance Inspection Report: BRPD-AB-2015-006, Bruce A and B Generating Stations Quarterly Field Inspection Report for Q1 2015-16, CNSC Letter, K. Lafrenière to F. Saunders, August 13, 2015.
- [115] NK29-CORR-00531-12162, CNSC Type II Compliance Inspection Report: BRPD-AB-2014-013, Environmental Monitoring at Bruce Site, CNSC Letter, K. Lafrenière to F. Saunders, December 9, 2014.
- [116] Bruce B OSART Mission: Advanced Information Package, Bruce Power 150251 R001, November 2015.
- [117] BP-PROC-00509-R004, Bruce A and B Quarterly Report on Safety Performance Indicators, December 15, 2014.
- [118] CC171-25E-PDF, Regulatory Oversight Report for Canadian Nuclear Power Plants: 2014, September 2015.
- [119] CNSC DIS-12-02, Process for Establishing Release Limits and Action Levels at Nuclear Facilities, March 2001. Link to archived Web page: <http://nuclearsafety.gc.ca/eng/acts-and-regulations/consultation/comment/d-12-02.cfm>
- [120] NK21-CORR-00531-01159/NK29-CORR-00531-03050/NK37-CORR-00531-00266, Proposed Operational Radiation Protection and Environmental Action Levels for Bruce Power Facilities, CNSC Letter, J.P. Van Berlo to F. Saunders, September 25, 2002.
- [121] DPT-PE-00005-R000, Performance Requirements for Contamination Exhaust Control Filters, Bruce Power, February 23, 2005.
- [122] TWI-540-415-300-R01, Technical Instructions for the Performance Testing of Contaminated Air Filtration Systems, Kinectrics, April 1, 2011.
- [123] CSA N288.3.2-M85, High Efficiency Air-cleaning Assemblies for Normal Operation of Nuclear Facilities, CSA Standard, withdrawn September 2009.




	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## Appendix A – High-Level Assessments Against Relevant Codes and Standards

### A.1. **CSA N288.1-14 Guidelines for calculating derived release limits for radioactive material in airborne and liquid effluents for normal operation of nuclear facilities**

Bruce Power is required by the Canadian Nuclear Safety Commission (CNSC) to calculate Derived Release Limits (DRLs) and environmental Action Levels (ALs) for radionuclide releases to the environment from its nuclear facilities. DRLs and ALs for Bruce Nuclear Generating Station (NGS) B are described in NK29-REP-03482-00003 R002 [55], which uses the guidance and methodology specified in the Canadian Standards Association (CSA) Standard N288.1-08, Update No. 1 [70]. NK29-REP-03482-00003 R002 also took into account the results of 2011 site specific survey for the Bruce Power site [82] and used the most recent meteorological data. However, since this report was written, CSA N288.1-14 has been issued [30]. This standard is intended to provide guidance for DRL calculations and supersedes the previous editions published in 2008 and 1987. The major differences between this standard (CSA N288.1-14, March 2014) and the previous edition of this Guideline (CSA Standard N288.1-08, Update No. 1) include:

- (a) updated energy expenditures and dietary intake rates for humans (e.g., as per Clauses in Section 6.15.1);
- (b) updated half-lives (Annex E), gamma energies, and photon yields for all radionuclides (Table H.2);
- (c) updated values for many parameters based largely on a new International Atomic Energy Agency handbook of parameter values for environmental transfers of radionuclides (IAEA, 2010) – E.g. as per Clauses in Sections 6.3.4.4, 6.9.1.4, 6.9.2.2, 6.9.3.2, 6.10.4.1, 7.7.2.4, 7.8.2, etc.;
- (d) improved direction on when the Guideline can be used to calculate DRLs for intermittent releases (e.g., as per Clauses in Sections 8.2.2 and 8.2.3.1);
- (e) updated wind direction and precipitation data for use in the wet deposition model (e.g., as per Clauses in Section 8.2.3.1);
- (f) introduction of a model for wild waterfowl as an additional source of human exposure through ingestion (e.g., as per Clauses in Sections 6.9.1.5, 6.9.2.3, 6.10.1.4, 6.11.1.3, 7.9.1.1, 7.9.1.2, 7.9.2);
- (g) extension of the carbon-14 (C-14) specific activity model to cover plant to animal transfer (e.g., as per Clauses in Sections 6.9.4, 6.10.4.2, 7.7.5.4 – 7.7.5.6);
- (h) an improved specific activity model for tritium in animals, including an update and extension of the water intake source fractions for fresh and dry feed (e.g., as per

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

Clauses in Sections 6.9.4, 7.7.4.2, 7.7.4.5, 6.9.1.1, 6.9.2.3, 6.10.1.1, 6.10.2.2, 6.10.2.3, 6.12.1.4); and

- (i) provision of equations for explicit accounting of decay and progeny ingrowth in all physical media, as an alternative to the use of progeny-inclusive dose coefficients (e.g., as per Clauses in Sections 4.3.2, 4.3.3, 4.3.4, 4.3.9, 4.3.10, 4.3.11, Annex I).

Clauses for which there have been changes to parametric values (such as 6.2.7, 6.3.3.3, 6.3.3.4, 6.3.6.3, 6.4.4, 6.4.8.4, 6.4.9.3, 6.5.5.2, 6.6.2.2, 6.6.2.4, 6.9.1.3, 7.11.2) will have to be reviewed again and taken into consideration when revising the DRLs.

There are also new clauses that provide guidance for calculating the transfer of radionuclides from pond water to pond sediment (see Clause 6.6.2.6). Section 6.9 has been revised to cover transfer from ponds and wells to plant produce (in addition to animal produce). Guidance related to organically-bound tritium (OBT) has also been updated as per clauses in Sections 6.10.3.1 and 6.10.3.2. In addition, CSA N288.1-14 indicates more conservative drinking water intake rates and recommends using the 95<sup>th</sup> percentiles in DRL calculations instead of 90<sup>th</sup> percentiles, as previously used in CSA N288.1-8, Update No. 1 (see Clause 6.15.3.1).

The updated guidance as provided in the latest version of CSA N288.1-14 is being factored into revised DRL calculations (see Section 5.5)

## **A.2. CSA N288.4-10, Environmental monitoring programs at Class I nuclear facilities and uranium mines and mills**


This standard is a greatly expanded and revised version of the earlier standard N288.4-M90. In the licence renewal application of October 31, 2013 [19], Bruce Power provided implementation and transition measures, and committed to full implementation of N288.4-10 by December 2018. In subsequent correspondence with the CNSC [70], Bruce Power confirmed this completion date, and added that they expect to be in compliance with the companion CSA Standards N288.5 [32] and N288.6 [33] by December 2018. These commitments were subsequently included in the LCH [2]. Some Bruce Power documents, such as BP-PROC-00076 [52], have already been revised to include reference to the requirements of N288.4-10 (issued May 2010).

## **A.3. CSA N288.5-11, Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills**

This is a new standard issued April 2011. Bruce Power has committed to be in full compliance with it by December 2018 [70].

## **A.4. CSA N288.6-12, Environmental risk assessments at Class I nuclear facilities and uranium mines and mills**

This is a new standard issued June 2012. The screening-level assessment report it requires was completed in March 2013 [63], and the higher-level assessment report was completed in

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

January 2015 [64]. Bruce Power has committed to use these reports to develop and implement the compliance plans for N288.4 and N288.5, mentioned above [70].

In future, the procedure DPT-ENV-00016 [57] will trigger a review of the ERA Report at least every five years.

#### **A.5. IAEA NS-G-3.2, Dispersion of Radioactive Material in Air and Water and Consideration of Population Distribution in Site Evaluation for Nuclear Power Plants**

The scope of IAEA Safety Guide NS-G-3.2 (March 2002) is to provide guidance for the site evaluation stage of a nuclear power plant and to assess the effects of the proposed plant on the uses of land and water in the region of the site. Also, as stated in the safety requirements document: Site Evaluation for Nuclear Installations [41], the scope of this document is to perform a detailed evaluation of the candidate site as part of the siting process for a nuclear installation. As such, IAEA NS-G-3.2 is not applicable to this Safety Factor report, and in addition the site has already been selected and the Bruce B NGS has already been built.

Those clauses of NS-G-3.2 related to environmental pathway modeling that may also be applicable to operating nuclear power plants are fully addressed by the CSA Standard, N288.1-08 [71], as well as by its revision, N288.1-14 [30].

#### **A.6. CNSC G-129, Revision 1, Keeping Radiation Exposures and Doses “As Low As Reasonably Achievable”**

CNSC Regulatory Guide G-129, R001, October 2014 is primarily concerned with maintaining worker doses As Low As Reasonably Achievable (ALARA), but it contains guidance related to maintaining public doses ALARA as well.


Clause 7.3.1, Resources, includes the statement, “resources for monitoring the environment beyond the workplace that is affected by operations should be identified and provided.”

Bruce Power provides the resources necessary to operate the Radiological Environmental Monitoring Program (REMP) [52], which satisfies this recommendation.

Clause 7.3.3, Environmental Monitoring, recommends that management receive summary reviews of the results of environmental monitoring and ensure that radionuclide emissions to the environment be kept ALARA.

Clause 8.2, Substantiation, includes the considerations for deciding what is ALARA, analyses of trends of doses to workers and to the public, and of radioactive effluent releases and environmental monitoring results.

The recommendations of these two clauses are satisfied by the annual Environmental Monitoring Program (EMP) Report (e.g., [62]), which includes both reviews of the results of environmental monitoring and analysis of trends of releases and environmental monitoring results.

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

#### **A.7. ANSI/HPS N13.1-1999 (R2011), Sampling and Monitoring Releases of Airborne Radioactive Substances From the Stacks and Ducts of Nuclear Facilities**

Most of the content of this American standard is addressed in CSA Standard N288.5-11 [32], but the latter document does not provide guidance on the setting of automatic alarm levels for airborne emissions. This topic is addressed in Section 4.4 of the American standard, and is referenced in Section 5.9 of the present report.

#### **A.8. CNSC G-228, Developing and Using Action Levels**

CNSC Regulatory Guide G-228, March 2001 [24], is primarily intended to provide high level guidance for developing, using and revising ALs for radiation protection of workers and the public during the conduct of activities licensed by the CNSC.

Clause 6.0, Developing, Using and Revising Action Levels, includes the statement “If it is to be useful and credible, an action level must be a meaningful indicator over a defined time period of the state of a radiation protection program. Accordingly, the action level must be measurable to accepted standards of accuracy”.

Further G-228 requires that an AL take into account the facility design and relevant operating experience. The AL should also be thoroughly and clearly explained and the rationale for the level and its planned use provided.


In BP-PROC-00171 [54], it is stated that the Emission Effective Dose (EED) was applied to provide a public dose basis for defining ALs. The basis of the ALs for each airborne and waterborne radionuclide group was chosen to: “achieve an equitable implied level of protection of the public and environment across all radionuclide emissions and across all Bruce Power facilities” (Section 4.3). Also, the AL set points are low enough such that a potential loss of control of emissions is identified and corrected well before any Regulatory limits are reached. ALs are also high enough to allow the facility to manage emissions beyond the normal range when a loss of control has not occurred.

BP-PROC-00171 discusses the changes to ALs that require CNSC approval and that are carried out as follows [35]:

- Calculate new ALs.
- Prepare and issue report detailing the methodology used and the results.
- Issue request to the CNSC for approval of revised ALs.

Bruce Power also has a commitment to review and if necessary revise the ALs specified in the LCH [2] at least once per licence period in order to validate their effectiveness.

CNSC has issued a discussion paper, Process for Establishing Release Limits and Action Levels at Nuclear Facilities [119], where it is acknowledged that G-228 “focuses on the use of ALs within the radiation protection program (predominantly for workers), rather than environmental protection in general” and that it “does not provide specific guidance for

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

numerically deriving ALs” (Section 4.6). Therefore, although the BP procedure BP-PROC-00171 [54] and report NK29-REP-03482-00003 [55] do not explicitly indicate that the AL was derived using guidance from G-228, CNSC has reviewed and accepted the proposed environmental ALs for Bruce Power [120].

As a result of response to the discussion paper DIS-12-02 [119], a new CSA standard, N288.8 on ‘Establishing and implementing action levels to control releases to the environment from nuclear facilities’, is currently being prepared to provide guidance for establishing and implementing ALs to control emissions from nuclear facilities, and it is expected to support G-228. Compliance with the Standard will allow Bruce Power to demonstrate continuous improvement for revising its ALs.


#### **A.9. CSA N288.3.4-13, Performance testing of nuclear air-cleaning systems at nuclear facilities**

Sections 4, 5, 6 and 7 of this Standard [44] address the objectives, design criteria and design of an air-cleaning system testing program. The present assessment is focused on compliance with the subsequent sections of the Standard, which are relevant to the ongoing operation of the program at Bruce B.

Section 8 of this Standard lists the types of performance tests that should be documented (or referenced) and conducted. Some are given as recommendations (“should”) and some as requirements (“shall”). These are listed below, with reference to the Bruce Power document in which they are mentioned, where applicable:


- Section 8.2 Visual inspection (recommendations only): Clause 4.2.4 of DPT-PE-00005 [121] requires that a, “Surveillance test of HEPA [High Efficiency Particulate Air] filter and carbon adsorber systems shall be made at regular intervals after installation to detect deterioration and leaks that may develop under normal service conditions.” The intent of the standard is met.
- Section 8.3 In-place instrument calibration verification (recommendations: Clause 5(e) of B-ST-03480-10000 [68]) requires that, “A stack flow measurement/velocity profile must be performed annually and calibrated/compared against a reference method.” It goes on to specify that the stack flow measurement be within 20% of the measured air stream by the reference method. The intent of the standard is met.
- Section 8.4 Duct, damper, and housing leak tests: These tests are only required at commissioning and following upset or maintenance that may affect performance. Since commissioning and refurbishment preceded issuing of the Standard, this requirement does not apply.
- Section 8.5 Air flow and pressure measurements: Clause 4.7.2 of BP-PROC-00080 [53] requires, “Effluent flow rates shall be determined because they directly impact the accuracy of the emissions and emission estimates.” In Table 1 of B-ST-03480-10000 [68], it is specified that a stack flow measurement be performed annually. In the document, Bruce Power Stack Filter Testing (Appendix A to the contract for testing of air cleaning systems by Kinectrics [79]), stack flow/monitor testing services are required



 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

annually for most stacks, and semi-annually for Emergency Filter Air Discharge Systems (EFADS) and Irradiated Fuel Bay (IFB) stacks. There is no discussion of air pressure measurements. The absence of ongoing air pressure measurements is assessed as a gap against guidance.

- Section 8.6 Air-aerosol mixing uniformity verification: This test is only required at commissioning and following system modification that may invalidate previous results. Since commissioning and refurbishment preceded issuing of the Standard, this requirement does not apply.
- Section 8.7 HEPA filter bank bypass test: The test frequency and leakage limits for HEPA filters are specified in DPT-PE-00005 [121], both for EFADS and for normal operation filters. The specific stacks whose filters require annual testing are listed in the document, Bruce Power Stack Filter Testing [79]. Detailed instructions on the performance of this test are given in a document prepared by the vendor of the test service, Kinectrics Technical Work Instruction, TWI-540-415-300 [122]. This Instruction is based on relevant American Society of Mechanical Engineers standards and U.S. Nuclear Regulatory Commission Regulatory Guides.
- Section 8.8 Adsorber bank bypass test: The test frequency and leakage limits for carbon filters are specified in DPT-PE-00005 [121], both for EFADS and for normal operation filters. The specific stacks whose filters require annual testing are listed in the document, Bruce Power Stack Filter Testing [79]. Detailed instructions on the performance of this test are given in a document prepared by the vendor of the test service, Kinectrics Technical Work Instruction, TWI-540-415-300 [122].
- Section 8.9 Laboratory testing of adsorbent media: This section requires both pre-service and in-service testing of adsorbent media (activated carbon). According to DPT-PE-00005 [121], there is no acceptance testing or in-service testing of filter carbon. Instead, it refers to an Ontario Power Generation purchase specification and an (obsolete) CSA standard (N288.3.2-M85 [123]) as providing quality assurance of new carbon. In addition, it states that "Application-specific studies of the carbon that has been in service in safety system filters" provides quality assurance. Consequently, this requirement of the Standard is not met and is assessed as a gap against requirements.
- Section 8.10 Combined test for adsorber bank bypass and media adsorbency: This is described as an alternative test to Freon bypass and laboratory testing of the media, where consistent with facility operations.
- Section 8.11 Whole system bypass test: This test is required where air-cleaning systems include ducts and dampers to bypass the filters when they are not required. It is only required at commissioning, and should be conducted following upsets or maintenance that might have affected the condition or operation of the ducts and dampers. Since commissioning and refurbishment preceded issuing of the Standard, this requirement does not apply.
- Section 8.12 Air heater performance test: This test is done where there is an air heater in the air-cleaning system to reduce the relative humidity of air entering the adsorber banks, and is required only at commissioning and following maintenance or upset that

	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

may have affected its performance. Since commissioning and refurbishment preceded issuing of the Standard, this requirement does not apply.

- Section 8.13 Fan performance test: Fan testing is required only at commissioning and following upset or maintenance that may have affected its performance. Since commissioning and refurbishment preceded issuing of the Standard, this requirement does not apply.

**Section 9 Interpretation of data:** This section is mostly guidance, but it implies a requirement that sampling errors be kept to a minimum by the design of the testing program. It also implies a requirement that the number of significant figures quoted in monitoring test results not imply an unwarranted degree of accuracy. There is no discussion of uncertainties related to filter testing or flow rate measurement in the Bruce Power documents, and so this is assessed as a gap against guidance.


**Section 10 Quality assurance and quality control:** This section requires that all aspects of the testing program have appropriate Quality Assurance/Quality Control (QA/QC) in accordance with CSA N286 [29]. There is no mention of QA/QC in DPT-PE-00005 [121], but Bruce Power Stack Filter Testing [79] says in Clause 3.1 (4) that a Kinectrics deliverable is to “Develop a QA/QC plan in collaboration with Bruce Power.” The Kinectrics document TWI-540-415-300 [122] includes aspects of QA/QC such as personnel qualification/experience, calibration/check standards and quality control measures. The absence of appropriate QA/QC guidance in Bruce Power governing documents is assessed as a gap against requirements.

**Section 11 Reporting, review, and auditing:** There is no requirement to report the results of filter testing to the CNSC. No record was found of reviews (such as self-assessments) or independent audits of the air-cleaning system performance testing program, and this is assessed as a gap against requirements.

**Section 12 Staff qualification and training:** The document Bruce Power Stack Filter Testing [79] says only that a Kinectrics deliverable is to “Deliver a team of full-time technical experts that are knowledgeable in all aspects of the program at the Bruce Site” (Clause 3.1 (1)). The Kinectrics document TWI-540-415-300 [122] in Section 2.0 describes in some detail the required qualifications of their personnel who conduct air filter performance testing. This does not meet the requirement of the Standard that the operator define the qualifications and that “If work is contracted out, documentation shall be available to demonstrate that the contract personnel have equivalent requisite qualifications” (Section 12). Consequently, this is assessed as a gap against requirements.

**Section 13 Documentation:** This section contains a list of the documentation required of the program. While some of this documentation is provided in the documents mentioned above, much of it is missing, and so this is assessed as a gap against requirements.


SCR 28506718 was initiated in July 2015 to perform a gap analysis of Bruce Power’s conformance with the requirements of CSA N288.3.4-13. This led to the identification of gaps and the creation of a correction action plan to address those gaps. As a result, Bruce Power is expected to be in conformance with the standard by September 30, 2016, and the gaps identified above will be closed.

 <small>Division of Kinectrics Inc.</small>	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

**A.10. CSA N288.7-15, Groundwater protection programs at Class I nuclear facilities and uranium mines and mills**

This is a new standard, whose purpose is, “to provide requirements and guidance which facilitate groundwater protection at *Class I nuclear facilities and uranium mines and mills*.” It describes in detail the design of a groundwater protection program, which includes a groundwater monitoring program. Bruce Power has an annual groundwater monitoring program that has been developed over the last 16 years. However, that program does not meet the requirements of this standard, and there is no documented groundwater protection program in place. Based on a FASA that assessed compliance with a draft of the standard in December 2014 (SA-ENV-2014-01 [90], see Section 7.1), actions are in progress to establish a groundwater protection program and to demonstrate compliance with CSA Standard N288.7-15 by March 2016.



	Rev Date: September 20, 2016	Status: Issued
	Subject: Safety Factor 14 - Radiological Impact on the Environment	File: K-421231-00214-R00

## Appendix B – Clause-By-Clause Assessments Against Relevant Codes and Standards

No codes or standards relevant to Safety Factor 14 were subjected to a clause-by-clause assessment. This Appendix is retained only for consistency with the Appendix numbering scheme in all other Safety Factor Reports.